



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C0677a - RSPCA - WACOL

C0677a-0010(A).xls

LIGHTING CONTROL SCHEDULE

REVISION A - 01 JULY 2010

MISCELLANEOUS EQUIPMENT			REV
ITEM	DESCRIPTION	BUS	
SP1	REFER TO THE EQUIPMENT SCHEDULE SP1 IS NOT A DYNALITE SWITCHPANEL	NA	A
SP2	DYNALITE 8-BUTTON STAINLESS STEEL PROGRAMMABLE SWITCHPANEL DYNALITE DPN 980 C/W ENGRAVED CAPS	A	A
SP3	DYNALITE 8-BUTTON STAINLESS STEEL PROGRAMMABLE SWITCHPANEL DYNALITE DPN 980 C/W ENGRAVED CAPS	A	A

DIMMER RACK 1					REV	
TYPE: DYNALITE DBC-1210 C/W RCD PROTECTION ON EACH OUTPUT SUPPLIED FROM: DB-BG1 - L6 BUS: A					A	
CHANNEL	SW / DIM / CONT	LUMINAIRES		CONTACTOR CIRCUIT	LOAD WATTS	
		LOCATION	TYPE			
1	SW / DIM	BOARD ROOM	D10			A
2	SW / DIM	BOARD ROOM	D10			A
3	SW / DIM	BOARD ROOM	D10			A
4	SW / DIM	BOARD ROOM	D10			A
5	SW / DIM	BOARD ROOM	D10			A
6	SW / DIM	BOARD ROOM	D10			A
7	SW / DIM	BOARD ROOM	D10			A
8						A
9						A
10						A
11						A
12						A