



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3067a - THE LION RICHLANDS - MINOR PROJECTS

C3067a-0004(A).xls

DISTRIBUTION BOARD DB-1

REVISION A - 20 MAY 2024

							REV
UPGRADE THE EXISTING DISTRIBUTION BOARD DB-1 AS NECESSARY TO ACCOMMODATE THE FOLLOWING CIRCUITS AND ASSOCIATED DYNALITE CONTROLS. REMOVE ALL EXISTING SWITCHGEAR MADE REDUNDANT BY THE WORKS AND UPDATE THE SCHEDULE AT PRACTICAL COMPLETION.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5	ENTRY	AUTO DOOR	A
P2	1	20	RCBO	2.5	AMENITY	HAND DRYER	A
P3	1	20	RCBO	2.5	AMENITY	SENSORS	A
P4	1	20	RCBO	2.5	AMENITY	HAND DRYER	A
L1	1	20	RCBO	2.5	ENTRY	LIGHTS	A
L2	1	20	RCBO	2.5	AMENITY	LIGHTS	A
L3	1	20	RCBO	2.5	AMENITY	LIGHTS	A
L4	1	20	RCBO	2.5	AMENITY	LIGHTS	A
L5	1	20	RCBO	2.5	AMENITY	LIGHTS	A