

ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3179a - SUNNYBANK COMMUNITY SPORTS CLUB

C3179a-0004(G).xls

LIGHTING CONTROL SCHEDULE

REVISION G - 16 OCTOBER 2025

MISCELLANEOUS EQUIPMENT					REV
ITEM	DESCRIPTION				
SP1	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP2	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP3	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP4	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP5	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP6	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP7	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP8	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP9	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
PE CELL	PROGRAMMABLE PE CELL DUS 90CS CONFIRM THE LOCATION ON SITE WITH THE ARCHITECT				A
TIME CLOCK	PROGRAMMABLE TIME CLOCK ENVISION GATEWAY PDEG C/W INTERNET ACCESS LOCATE DB-B				A
CONTROL MODULE 1					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-1-1			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
1-1	DALI DIM	LEVEL 1 HALL	DB-1-1 - L4	L6	A
1-2	DALI DIM	LEVEL 1 FUNCTION RM	DB-1-1 - L7	L9	A
1-3	DALI DIM	LEVEL 1 FUNCTION RM	DB-1-1 - L6	L9	A
1-4	DALI DIM	LEVEL 1 BOARD RM	DB-1-1 - L6	L9	A
1-5	DALI DIM	LEVEL 1 ENTRY	DB-1-1 - L5	L6	A
1-6					A
1-7					A
1-8					A
1-9					A
1-10					A
1-11					A
1-12					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3179a - SUNNYBANK COMMUNITY SPORTS CLUB

C3179a-0004(G).xls

LIGHTING CONTROL SCHEDULE

REVISION G - 16 OCTOBER 2025

CONTROL MODULE 2					A
TYPE:		DYNALITE DDMC802			A
DESCRIPTION		8 CHANNEL MULTIPURPOSE CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-1-1			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
1-13	SWITCHED DGRM204 CH 1	LEVEL 1 OFFICE	DB-1-1 - L2	L1 L2	A
1-14					D
1-15	SWITCHED DGRM204 CH 1	LEVEL 1 OFFICE	DB-1-1 - L2	SIGN	D
1-16					A
1-17					A
1-18					A
CONTROL MODULE 3					A
TYPE:		DYNALITE DDMC802			A
DESCRIPTION		8 CHANNEL MULTIPURPOSE CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-G4			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
4-1	SWITCHED DGRM204 CH 1	FUNCTION ROOM	DB-G4 - L1	L22	C
4-2	SWITCHED DGRM204 CH 1	FUNCTION ROOM	DB-G4 - L1	L23 L24	A
4-3	SWITCHED DGRM204 CH 1	FUNCTION ROOM	DB-G4 - L1	L23 L24	A
4-4					A
4-5					A
4-6					A
CONTROL MODULE 4					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-G4			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
4-13	DALI DIM	FUNCTION ROOM	DB-G4 - L1	L37	A
4-14	DALI DIM	FUNCTION ROOM	DB-G4 - L1	L33	A
4-15	DALI DIM	FUNCTION ROOM	DB-G4 - L2	L33	A
4-16	DALI DIM	FUNCTION ROOM	DB-G4 - L3	L33	A
4-17	DALI DIM	AMENITIES	DB-G4 - L3	L37	A
4-18	DALI DIM	AMENITIES	DB-G4 - L3	L36	A
4-19					F
4-20	DALI DIM	BAR	DB-G4 - L4	L14	A
4-21					A
4-22					A
4-23					A
4-24					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3179a - SUNNYBANK COMMUNITY SPORTS CLUB

C3179a-0004(G).xls

LIGHTING CONTROL SCHEDULE

REVISION G - 16 OCTOBER 2025

CONTROL MODULE 5					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-G5			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
5-1	DALI DIM	LIFT LOBBY	DB-G5 - L1	L9	A
5-2	DALI DIM	BISTRO ENTRY	DB-G5 - L1	L18 L19 L20 L30	A
5-3	DALI DIM	FUNCTION ENTRY	DB-G5 - L1	L27	A
5-4					A
5-5					A
5-6					A
5-7					A
5-8					A
5-9					A
5-10					A
5-11					A
5-12					A
CONTROL MODULE 6					A
TYPE:		DYNALITE DDMC802			A
DESCRIPTION		8 CHANNEL MULTIPURPOSE CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-G5			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
5-13	SWITCHED DGRM204 CH 1	BISTRO ENTRY	DB-G5 - L1	L26	A
5-14	SWITCHED DGRM204 CH 1	BISTRO ENTRY	DB-G5 - L1	SIGN	D
					A
CONTROL MODULE 7					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12CH 20 A FEEDTHROUGH RELAY CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-G8			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
8-1	SWITCHED	EXTERNAL	DB-G8 - L1	L40	C
8-2	SWITCHED	BISTRO	DB-G8 - L2	L41	C
8-3	SWITCHED	BISTRO	DB-G8 - L2	L23 L24 L25	A
8-4	SWITCHED	BISTRO	DB-G8 - L2	L22	A
8-5	SWITCHED	BISTRO	DB-G8 - L2	L21	A
8-6	SWITCHED	BISTRO	DB-G8 - L2	L22	A
8-7					F
8-8	SWITCHED	BISTRO	DB-G8 - L6	L23 L24 L25	A
8-9	SWITCHED	FUNCTIONS	DB-G8 - L6	L23 L25	A
8-10	SWITCHED	BISTRO	DB-G8 - L6	L23 L24 L25	A
8-11	SWITCHED	FUNCTION ROOM ENTRY	DB-G8 - L7	SIGN	A
8-12	SWITCHED	ALFRESCO	DB-G8 - L6	L22	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3179a - SUNNYBANK COMMUNITY SPORTS CLUB

C3179a-0004(G).xls

LIGHTING CONTROL SCHEDULE

REVISION G - 16 OCTOBER 2025

CONTROL MODULE 8					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-G8			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
8-13	DALI DIM	BISTRO	DB-G8 - L8	L32	A
8-14	DALI DIM	BISTRO	DB-G8 - L18	L32	B
8-15	DALI DIM	BISTRO	DB-G8 - L18	L31	B
8-16	DALI DIM	BISTRO	DB-G8 - L9	L31	A
8-17	DALI DIM	BISTRO	DB-G8 - L10	L17	A
8-18	DALI DIM	BISTRO	DB-G8 - L11	L32	A
8-19	DALI DIM	BISTRO	DB-G8 - L11	L32	A
8-20	DALI DIM	BISTRO	DB-G8 - L11	L32	A
8-21	DALI DIM	BISTRO	DB-G8 - L11	L32	A
8-22	DALI DIM	BISTRO	DB-G8 - L12	L32	A
8-23	DALI DIM	BISTRO	DB-G8 - L12	L18	A
8-24	DALI DIM	BISTRO	DB-G8 - L12	L32	A
CONTROL MODULE 9					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-G8			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
8-25	DALI DIM	BISTRO	DB-G8 - L12	L32	A
8-26	DALI DIM	ALFRESCO	DB-G8 - L12	L32	A
8-27	DALI DIM	BISTRO	DB-G8 - L13	L28 L29	A
8-28	DALI DIM	BISTRO	DB-G8 - L13	L16	A
8-29	DALI DIM	ALFRESCO	DB-G8 - L14	L32	A
8-30	DALI DIM	ALFRESCO	DB-G8 - L14	L18 L19 20	A
8-31	DALI DIM	BISTRO	DB-G8 - L15	L39	A
8-32	DALI DIM	BISTRO	DB-G8 - L15	L18 L19 20	A
8-33	DALI DIM	BISTRO	DB-G8 - L15	L39	A
8-34	DALI DIM	BISTRO	DB-G8 - L16	L38	A
8-35	DALI DIM	BISTRO	DB-G8 - L16	L38	A
8-36	DALI DIM	BISTRO	DB-G8 - L18	L31	B
CONTROL MODULE 10					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-G8			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
8-37	DALI DIM	BISTRO	DB-G8 - L17	L15	A
8-38	DALI DIM	BISTRO	DB-G8 - L13	L42	B
8-39	DALI DIM	BISTRO	DB-G8 - L13	BAR DISPLAY	B
8-40	DALI DIM	BISTRO	DB-G8 - L2	L43	B
8-41	DALI DIM	BISTRO	DB-G8 - L17	L48	G
8-42					A
8-43					A
8-44					A
8-45					A
8-46					A
8-47					A
8-48					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3179a - SUNNYBANK COMMUNITY SPORTS CLUB

C3179a-0004(G).xls

LIGHTING CONTROL SCHEDULE

REVISION G - 16 OCTOBER 2025

CONTROL MODULE 11					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12CH 20 A FEEDTHROUGH RELAY CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-G8			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
8-49	SWITCHED	PLAY GROUND	DB-G8 - L5	FESTOON	A
8-50					A
8-51					A
8-52					A
8-53					A
8-54					A
8-55					A
8-56					A
8-57					A
8-58					A
8-59					A
8-60					A
CONTROL MODULE 12					B
TYPE:		DYNALITE DDMC802			B
DESCRIPTION		8 CHANNEL MULTIPURPOSE CONTROLLER			B
LOCATION		DIN RAIL MOUNTED WITHIN DB-G6 OR AN ADJACENT ENCLOSURE IF REQUIRED			B
BUS:		A			B
CHANNEL	CONTROL	DESCRIPTION			B
		LOCATION	CIRCUIT	USE	B
6-1	SWITCHED DGRM204 CH 1	SOLE CASA ENTRY	DB-G6 - L3	SIGN	B
6-2	DALI DIMMED DGBM200 CH 1	SOLE CASA ENTRY		L46	F
6-3	DALI DIMMED DGBM200 CH 1	ATM		L46	F
6-4	DALI DIMMED DGBM200 CH 2	SOLE CASA ENTRY		L46	F
					B