



PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS. PROVIDE THE DB WITH AN AS2293 EMERGENCY LIGHTING CONTROL SYSTEM TO CONTROL THE ASSOCIATED EMERGENCY LIGHTS. PROVIDE THE DB WITH SURGE PROTECTION. REFER TO THE NOTES FOR ADDITIONAL REQUIREMENTS.

CIRC	PH	CIRCUIT	CONTROL	CABLE	LOCATION	CIRCUIT
		BREAKER (amps)	EQUIPMENT	SIZE (mm2)		USE
P1	3	50	MCB	10	WAREHOUSE	INV 1
P2	3	50	MCB	10	WAREHOUSE	INV 2
P3	1	20	RCBO	2.5	WAREHOUSE	GPO
P4	3	20	RCBO	2.5	WAREHOUSE	SLIDING DOOR
P5	3	20	RCBO	2.5	WAREHOUSE	SLIDING DOOR
P6	3	20	RCBO	2.5	WAREHOUSE	ROLLER SHUTTER DOOR
P7	3	20	RCBO	2.5	WAREHOUSE	SLIDING DOOR
P8	3	20	RCBO	2.5	WAREHOUSE	EXHAUST FAN
P9	1	20	RCBO	2.5	WAREHOUSE	BIG ASS FAN
P10	1	20	RCBO	2.5	WAREHOUSE	BIG ASS FAN
P11	1	25	RCBO	4	WAREHOUSE	BIG ASS FAN
L1	1	20	RCBO SP	2.5	WAREHOUSE	LIGHTING
L2	1	20	RCBO SP	2.5	WAREHOUSE	LIGHTING
L3	1	20	RCBO SP	2.5	WAREHOUSE	LIGHTING
L4	1	20	RCBO SP	2.5	WAREHOUSE	LIGHTING
L5	1	20	RCBO SP	2.5	WAREHOUSE	LIGHTING
L6	1	20	RCBO PE CELL ON DUSK TC OFF 10.00PM	2.5	EXTERNAL	SECURITY LIGHTING
L7	1	20	RCBO PE CELL ON DUSK TC OFF 10.00PM	2.5	EXTERNAL	DECORATIVE LIGHTING

