



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3630a - JIMBOOMBA TAVERN

C3630a-0005(A).xls

DISTRIBUTION BOARD DB-L

REVISION A - 24 OCTOBER 2025

<div> <div>FAULT CURRENT: 6KA</div> <div>CHASSIS SIZE: 48 POLE</div> <div>CHASSIS RATING: 250A</div> <div>PHASES: 3</div> </div> <div> <div>MAIN SWITCH: 250 NON AUTO LOAD BREAK</div> <div>SOURCE: MDB</div> <div>SUPPLY CABLE: 4C+E 25</div> </div>							REV
							A
							A
							A
							A
REFER TO THE EQUIPMENT SCHEDULE AND NOTES FOR ADDITIONAL REQUIREMENTS. PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS IN ADDITION TO THE CONTROLS INCLUDING THE DYNALITE EQUIPMENT PROVIDED AS PART OF THE INITIAL WORKS. PROVIDE THE DB WITH AN AS2293 EMERGENCY LIGHTING CONTROL SYSTEM TO CONTROL THE ASSOCIATED EMERGENCY LIGHTS. PROVIDE THE DB WITH SURGE PROTECTION. ENSURE THE SCHEDULE INCLUDES THE CIRCUIT USE AND LOCATION.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE ( mm <sup>2</sup> )	LOCATION	CIRCUIT USE	A
P1	1	20	RCBO	2.5	BISTRO BAR	GLASS WASHER	A
P2	1	20	RCBO	2.5	BISTRO	ICE CREAM	A
P3	1	20	RCBO	2.5	SPORTS BAR	TV	A
P4	1	20	RCBO	2.5	SPORTS BAR	LED SCREEN	A
P5	1	20	RCBO	2.5	SPORTS BAR	LED SCREEN	A
P6	1	20	RCBO	2.5	EXTERNAL	LED SCREEN	A
P7	1	20	RCBO	2.5	EXTERNAL	LED SCREEN	A
P8	1	20	RCBO	2.5	EXTERNAL	LED SCREEN	A
L1	1	20	RCBO	2.5		LIGHTING	A
L2	1	20	RCBO	2.5		LIGHTING	A
L3	1	20	RCBO	2.5		LIGHTING	A
L4	1	20	RCBO	2.5		LIGHTING	A
L5	1	20	RCBO	2.5		LIGHTING	A
L6	1	20	RCBO	2.5		LIGHTING	A
L7	1	20	RCBO	2.5		LIGHTING	A
L8	1	20	RCBO	2.5		LIGHTING	A
L9	1	20	RCBO	2.5		LIGHTING	A
L10	1	20	RCBO	2.5		LIGHTING	A
L11	1	20	RCBO	2.5		LIGHTING	A
L12	1	20	RCBO	2.5		LIGHTING	A
L13	1	20	RCBO	2.5		LIGHTING	A
L14	1	20	RCBO	2.5	BISTRO BAR	HEAT LAMPS	A
							A
							A