

# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3638a - KENSINGTON TAVERN					C3638a-0002(B).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION B - 03 NOVEMBER 2025					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK <a href="http://www.edg.net.au/Links/Lighting.htm">www.edg.net.au/Links/Lighting.htm</a>					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S1	RGB3000K LED	VERTICAL LED RGB WW STRIPS WITHIN A SCREW FIXED EXTRUSION MOUNTED ON THE LEADING EDGE OF THE FEATURE TIMBER AS PER THE MAIN ENTRY WALL LIGHTING ELEVATION AND THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH A RGB CONTROL SYSTEM AS PER THE RGB CONTROL SCHEMATIC WITH ONE SLAVE CONTROLLER / POWER SUPPLY PER 10M OF STRIP LOCATE THE SLAVE CONTROLLERS AND POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	BLACK HOUSING	NPA -SF16 RGB 3000K + HOUSING	A
S2	16W/M 2700K LED	25MM DIA IP67 FLEXIBLE LED ROPE SCREW FIXED TO THE CEILING WITH SUSPENSION AS DIRECTED BY THE ARCHITECT C/W REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED POSITION NOTED ON THE AS CONSTRUCTED DRAWINGS	FROSTED WHITE TUBE AND FIXINGS	CARIBOU LIGHTING D24	A
S3	14.4W/M 3000K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER RECESSED INTO THE REAR BAR JOINERY AS PER THE ARCHITECTURAL DETAIL. REFER TO THE ELEVATION FOR THE EXTENT. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	A
S4	14.4W/M 3000K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER WITHIN THE BAR FRONT FEATURE AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	A
S5	14W/M 3000K LED	LED STRIP TAPE FIXED TO THE REAR OF THE TV VIA DOUBLE SIDED HEAT RESISTANT TAPE. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED R2334 AND POWER SUPPLY & DALI CONTROLLER	A
S6	14.4W/M 3000K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER WITHIN THE BAR FRONT FEATURE AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3638a - KENSINGTON TAVERN					C3638a-0002(B).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION B - 03 NOVEMBER 2025					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK <a href="http://www.edg.net.au/Links/Lighting.htm">www.edg.net.au/Links/Lighting.htm</a>					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S7	14.4W/M 3000K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER WITHIN THE CURTAIN PELMET PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	A
S8	10W/M 3000K LED	IP67 LED FLEX SCREW FIXED INTO THE CORNICE AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 + POWER SUPPLY & DALI CONTROLLER	A
S9	10W/M 3000K LED	IP67 LED FLEX SCREW FIXED BEHIND THE MIRROR AS PER THE ARCHITECTURAL DETAIL. REFER TO THE ELEVATION FOR THE EXTENT. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 + POWER SUPPLY & DALI CONTROLLER	A
S10	10W/M 3000K LED	IP67 LED FLEX SCREW FIXED BEHIND THE MIRROR AS PER THE ARCHITECTURAL DETAIL. REFER TO THE ELEVATION FOR THE EXTENT. PROVIDE THE STRIP WITH REMOTE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 + POWER SUPPLY & DALI CONTROLLER	A
S11	14.4W/M 3000K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER WITHIN THE ROOF TURRET AT HIGH LEVEL. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	B
PD01	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 A60 LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	1000 LONG THREE LAMP DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	BLACK	FAT SHACK VINTAGE P438-BLK	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3638a - KENSINGTON TAVERN					C3638a-0002(B).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION B - 03 NOVEMBER 2025					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK <a href="http://www.edg.net.au/Links/Lighting.htm">www.edg.net.au/Links/Lighting.htm</a>					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
PD02	TRAILING EDGE DIMMABLE 240 VOLT 2200K B22 ST64 FILAMENT TEARDROP LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	340 DIA HIGH DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	BLACK	FAT SHACK VINTAGE P312-RND- BLK	A
PDE1	SIX X TRAILING EDGE DIMMABLE 240 VOLT 2700K LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMPS	RELOCATE THE EXISTING 6 LAMP PENDANT AND REPLACE THE EXISTING LAMPS WITH NEW TE DIMMABLE LAMPS.			A
PDE2	TRAILING EDGE DIMMABLE 240 VOLT 2700K LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMPS	RESUPPLY THE EXISTING PENDANT AND REPLACE THE EXISTING LAMP WITH A NEW TE DIMMABLE LAMP.			A
PDE3	TRAILING EDGE DIMMABLE 240 VOLT 2700K LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMPS	RESUPPLY THE EXISTING PENDANT AND REPLACE THE EXISTING LAMP WITH A NEW TE DIMMABLE LAMP.			A
RD01	15W 2700K LED	REMOVE THE EXISTING FITTING AND REPLACE IT WITH A NEW RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1077-WH-125- WW-DALI	A
RD02	15W 2700K LED	REMOVE THE EXISTING FITTING AND REPLACE IT WITH A NEW RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	BLACK	RAPID R1075-WH- 15W-WW-DALI	A
RD03	15W 2700K LED	REMOVE THE EXISTING FITTING AND REPLACE IT WITH A NEW RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1077-WH-125- WW-DALI	B
RD04	15W 2700K LED	REMOVE THE EXISTING FITTING AND REPLACE IT WITH A NEW RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	BLACK	RAPID R1077-WH-125- WW-DALI	B
RD05	3W 3000K LED	REMOVE THE EXISTING FITTING AND REPLACE IT WITH A NEW RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER IT IS ACCEPTABLE TO SUPPLY MULTIPLE RD05 FITTINGS FROM A SUITABLY SIZED DRIVER ADJUST THE JOINERY AS NECESSARY TO ACCOMMODATE THE NEW DOWNLIGHT.	BLACK	SUPERLIGHT SL2258- 21	B



# ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3638a - KENSINGTON TAVERN					C3638a-0002(B).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION B - 03 NOVEMBER 2025					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK <a href="http://www.edg.net.au/Links/Lighting.htm">www.edg.net.au/Links/Lighting.htm</a>					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SL01	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 A60 LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE SURFACE MOUNTED FITTING PROVIDE A DALI TO PHASE CUT TRAILING EDGE CONVERTER TO ALLOW THE SL01 FITTINGS TO BE DIMMED VIA THE DALI SIGNAL. IT IS ACCEPTABLE TO DIM MULTIPLE SL01 AND SL02 FITTINGS FROM A SUITABLY SIZED COMMON CONVERTER. LOCATE THE CONVERTER IN A CONCEALED ACCESSIBLE POSITION IDENTIFIED ON THE AS BUILT DRAWINGS.	BLACK OPAL SHADE	FAT SHACK VINTAGE C205-OPL	A
SL02	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 A60 LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE SURFACE MOUNTED FITTING PROVIDE A DALI TO PHASE CUT TRAILING EDGE CONVERTER TO ALLOW THE SL02 FITTINGS TO BE DIMMED VIA THE DALI SIGNAL. IT IS ACCEPTABLE TO DIM MULTIPLE SL01 AND SL02 FITTINGS FROM A SUITABLY SIZED COMMON CONVERTER. LOCATE THE CONVERTER IN A CONCEALED ACCESSIBLE POSITION IDENTIFIED ON THE AS BUILT DRAWINGS.	BRASS / GOLD OPAL SHADE	FAT SHACK VINTAGE C205--GLDGAL-OPL	A
SL03	40W 4000K LED	REPLACE THE EXISTING BATTEN WITH A NEW 1200 LED BATTEN C/W INTEGRAL SDRIVER	GREY	RAPID LED HAWK-40 R3540-TRI	B
WL01	TRAILING EDGE DIMMABLE 240 VOLT 2700K E14 LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE 350 HIGH WALL LIGHT C/W INTEGRAL DRIVER MOUNTED AS PER THE ARCHITECTURAL DETAILS	BRASS	CARIBOU NLX6N2310521035	A
WL02	3000K GU10 LED	DECORATIVE IP65 WALL LIGHT TO ILLUMINATE UPWARDS MOUNTED AS PER THE ARCHITECTURAL DETAILS	WHITE	ABOUT SPACE NORDZ S IP65	B
L1	70W 4000K LED	EXISTING CARPARK POLE LIGHT. REPLACE THE EXISTING FITTING AND PROVIDE A BRACKET TO ALLOW THE NEW FITTING TO BE FIXED TO THE EXISTING POLE / MOUNTING. 15DEG TILT	BLACK	RAPID LED R3240- MED R09603	A
L2	52W 4000K LED PER FITTING	EXISTING CARPARK POLE LIGHT. REPLACE THE TWO EXISTING FITTINGS AND PROVIDE BRACKETS TO ALLOW THE NEW FITTINGS TO BE FIXED TO THE EXISTING POLE / MOUNTING. 15DEG TILT	BLACK	TWO X RAPID LED R3240-MED R09603	A
L3	35W 4000K LED PER FITTING	EXISTING CARPARK POLE LIGHT. REPLACE THE FOUR EXISTING FITTINGS AND PROVIDE BRACKETS TO ALLOW THE NEW FITTINGS TO BE FIXED TO THE EXISTING POLE / MOUNTING. 15DEG TILT	BLACK	FOUR X RAPID LED R3240-MED R09603	A
L4	12W 2700K LED	NEW RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER CIRCUIT THE L4 FITTINGS WITH THE ADJACENT L5 FITTINGS.	WHITE	R1075-WH-12W-WW- 60I	A
L5	EXISTING OFFICE SURFACE BATTEN TO BE RELOCATED TO THE NEW POSITION INDICATED.				A
G1	GAMING BASE KICK LED STRIP LIGHTS TO BE PROVIDED AS PART OF THE GAMING BASE AND CONNECTED BY THE GAMING ELECTRICIAN.				A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3638a - KENSINGTON TAVERN					C3638a-0002(B).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION B - 03 NOVEMBER 2025					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK <a href="http://www.edg.net.au/Links/Lighting.htm">www.edg.net.au/Links/Lighting.htm</a>					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
REMOVE		EXISTING LIGHT FITTING TO BE REMOVED.			A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	WHITE	CLEVERTRONICS LLIFE	A
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	WHITE	CLEVERTRONICS LUBPRO-SM	A
RGB MASTER CONTROLLER (MC)		RGB MASTER CONTROLLER WALL MOUNTED AT 1400AFFL. PROVIDE THE MASTER CONTROLLER WITH A POWER SUPPLY VIA A SINGLE GPO. CONNECT THE MASTER CONTROLLER TO THE SLAVE CONTROLLERS FOR THE ASSOCIATED CHANNEL AS PER THE RGB CONTROL SCHEMATIC. CONFIGURE AND LABEL THE CONTROLLER AS DIRECTED BY THE HOTEL MANAGEMENT ON SITE.		NPA-FL-E-RGBW-W4C	A
RGB SLAVE CONTROLLER (SC)		RGB SLAVE CONTROLLER PER 10M OF RGBWW LED STRIP. LOCATE THE SLAVE CONTROLLER AND ASSOCIATED POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION NOMINATED ON THE AS CONSTRUCTED DOCUMENTS. CONNECT THE SLAVE CONTROLLER TO THE MASTER CONTROLLER AND POWER SUPPLY AS PER THE RGB CONTROL SCHEMATIC.		NPA-FL-E-RGBW-S	A
CHANNEL x		CONTROL CHANNEL WITH A NUMERICAL REFERENCE. REFER TO THE POWER AND LIGHTING CONTROL SCHEMATIC / SCHEDULE			A
LIGHTING CONTROL SWITCH PANEL (SPx)		6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	ALUMINIUM	DYNALITE ANTUMBRA DISPLAY	A
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES FACEPLATE	A
PROXIMITY DETECTOR SWITCH (PD)		ADJUSTABLE FLUSH RECESSED 360 DEGREE PIR PRESENCE DETECTOR TO OPERATE THE ASSOCIATED LIGHTS FOR A PRE-SET AMOUNT OF TIME. ADJUST THE TIME AND SENSITIVITY ON SITE AS DIRECTED BY THE ENGINEER. SUBMIT DETAILS OF THE MOVEMENT DETECTOR SWITCH FOR APPROVAL PRIOR TO ORDERING	WHITE	CLIPSAL	A
HAND DRYER CONNECTION (HD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND FOR THE HAND DRYER MOUNT THE GPO AS PER THE ARCHITECTURAL DETAIL	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3638a - KENSINGTON TAVERN					C3638a-0002(B).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION B - 03 NOVEMBER 2025					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK <a href="http://www.edg.net.au/Links/Lighting.htm">www.edg.net.au/Links/Lighting.htm</a>					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
AUTO DOOR SINGLE POWER OUTLET (AD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION LOCATED CONCEALED WITHIN THE AUTO DOOR HEAD MULLION RATING 10A U.N.O.	WHITE	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
GAMING TAB OUTLET		GAMING / TAB OUTLETS PROVIDED BY THE GAMING ELECTRICIAN. REFER TO THE NOTES FOR ADDITIONAL DETAILS ON THE SCOPE.			A
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE GPO / ISOLATORS ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
DB-A		PROVIDE A NEW DISTRIBUTION BOARD DB-A AS PER THE DB-A SCHEDULE AND NOTES.			A
DB-CJB		NEW GAMING DISTRIBUTION BOARD DB-CJB TO BE PROVIDED BY THE GAMING ELECTRICIAN.			A
DB-G		EXISTING GAMING DISTRIBUTION BOARD DB-G TO BE REMOVED. ANY EXISTING CIRCUITS THAT REMAIN ARE TO BE RESUPPLIED FROM DB-A.			A
DB-CA		EXISTING DISTRIBUTION BOARD DB-CA TO REMAIN. REMOVE ALL EXISTING CIRCUITS MADE REDUNDANT BY THE WORKS. UPDATE THE SCHEDULE AT PRACTICAL COMPLETION.			A
DB-CB		EXISTING DISTRIBUTION BOARD DB-CB TO REMAIN. PROVIDE DB-CB WITH A NEW THREE PHASE 63 AMP CIRCUIT BREAKER TO SUPPLY DB-A. REMOVE ALL EXISTING CIRCUITS MADE REDUNDANT BY THE WORKS. UPDATE THE SCHEDULE AT PRACTICAL COMPLETION.			A
FIP		EXISTING FIRE INDICATOR PANEL TO BE UPGRADED AS NECESSARY TO ACCOMMODATE THE AUTO DOOR INTERFACE.			A
AUTO DOOR INTERFACE		INTERFACE THE FIRE ALARM SYSTEM INTO THE AUTO DOOR TO UNLOCK UPON ALARM			A