



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3843a - CAPALABA TAVERN

C3843a-0005(A).xls

DISTRIBUTION BOARD DB-A

REVISION A - 24 SEPTEMBER 2026

							REV
PROVIDE THE EXISTING DISTRIBUTION BOARD WITH THE FOLLOWING SWITCHGEAR. REMOVE ANY SWITCHGEAR MADE REDUNDANT BY THE WORKS AND UPDATE THE SCHEDULE AT PRACTICVAL COMPLETION.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	A
P1	1	20	RCBO	2.5	GAMING	TV	A
P2	1	20	RCBO	2.5	GAMING	CLEANING	A
P3	1	25	RCBO	4.0	BISTRO	TV	A
P4	1	20	RCBO	2.5	KITCHEN	CO2	A
P5	1	20	RCBO	4.0	DECK	TV	A
P6	1	20	RCBO	2.5	KITCHEN	REF	A
P7	1	32	RCBO	6.0	KITCHEN	PIZZA	A
P8	3	63	MCB	16.0	PLANT	DB-C	A
							A
							A
							A
							A
							A