

ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH						C2864a-0002(J).xls
ELECTRICAL EQUIPMENT SCHEDULE						
REVISION J - 28 MAY 2026						
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm						
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV	
L1	30W COOL WHITE LED	9m HIGH POLE C/W ENGINEER CERTIFIED FOOTING AND A CAR PARK LIGHT 15 DEG TILT	BLACK FITTING & POLE	SAL COMMERCIAL OCS3040NA75	C	
L2	30W COOL WHITE LED	7.8m HIGH POLE C/W A CAR PARK LIGHT MOUNTED ON A ENGINEER CERTIFIED 1200 HIGH 600 DIA REINFORCED CONCRETE BOLLARD / FOOTING. FITTING MOUNTED AT 9m. 15 DEG TILT	BLACK FITTING & POLE	SAL COMMERCIAL OCS3040NA75	C	
L3	36W LED 4000K	SURFACE MOUNTED IP66 1200 LONG BATTEN C/W INTEGRAL DRIVER AND OCCUPANCY SENSOR	LIGHT GREY	GAMMA STORM 1558-CCT-36+SENSOR	A	
L4	36W LED 4000K	SURFACE MOUNTED IP66 1200 LONG BATTEN C/W INTEGRAL DRIVER	LIGHT GREY	GAMMA STORM 1558-CCT-36	A	
L5	36W LED 4000K	SURFACE MOUNTED IP66 1200 LONG BATTEN C/W INTEGRAL DRIVER AND AN UNSWITCHED AS2293 NON MAINTAINED EMERGENCY PACK CONFIGURED TO ONLY OPERATE UPON MAINS FAILURE	LIGHT GREY	GAMMA STORM 1558-CCT-36	A	
L6	100W 4000K LED	HIGH BAY C/W INTEGRAL DRIVER CHAIN SUSPENDED	BLACK	GAMMA ILLUMINATION ORBIT 2 881538	A	
L7	90W COOL WHITE LED	9m HIGH POLE C/W ENGINEER CERTIFIED FOOTING AND A CAR PARK LIGHT 15 DEG TILT	BLACK FITTING & POLE	SAL COMMERCIAL OCS9040NA45	C	
L8	90W COOL WHITE LED	7.8m HIGH POLE C/W A CAR PARK LIGHT MOUNTED ON A ENGINEER CERTIFIED 1200 HIGH 600 DIA REINFORCED CONCRETE BOLLARD / FOOTING. FITTING MOUNTED AT 9m. 15 DEG TILT	BLACK FITTING & POLE	SAL COMMERCIAL OCS9040NA45	C	
L9	90W 5000K LED	SUSPENDED IP 65 VEHICLE ENTRY LIGHT C/W INTEGRAL DIMMABLE DRIVER AND ILLUMINATION LEVEL SENSOR. PROVIDE EACH VEHICLE ENTRY INSTALLATION WITH AN enLIGHTEN CECS CONTROLLER.	BLACK	EQUAL TO enLIGHTEN TAURO BLACK TB90D-57-S1-CECS	B	
L10	50W LED	ADJUSTABLE FLOOD LIGHT C/W INTEGRAL DRIVER MOUNTED ON THE BUILDING AS INDICATED.	BLACK	SAL COMMERCIAL FCB5050NAS1	C	
L11	13W 4000K LED	RECESSED DOWNLIGHT C/W REMOTE DRIVER	WHITE TRIM	GAMMA ILLUMINATION COBALT 1402-4K-13W	B	



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH					C2864a-0002(J).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION J - 28 MAY 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L12	22W 4000K LED	RECESSED DOWNLIGHT C/W REMOTE DRIVER	WHITE TRIM	GAMMA ILLUMINATION COBALT 1441-4K-22W	B
L13	34W 4000K LED	1200 x 300 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PB MOUNTING KIT	WHITE TRIM	GAMMA ILLUMINATION AXIS 1549-4K-34W C/W FLUSH RECESS PB KIT	A
L14	26W 4000K	600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PB MOUNTING KIT	WHITE TRIM	GAMMA ILLUMINATION AXIS 1548-4K-26W C/W FLUSH RECESS PB KIT	A
L15	3000K LED	CUSTOM DECORATIVE PENDANT C/W INTEGRAL LED CHIP SET AND REMOTE DALI DIMMABLE DRIVER. PROVIDE THE FITTING WITH A HANG SURE SUSPENSION KIT	RUST COPPER	LUMEN 8 BESPOKE DRY DOCK L15	E
L16	3000K LED	CUSTOM DECORATIVE PENDANT C/W INTEGRAL LED CHIP SET AND REMOTE DALI DIMMABLE DRIVER. PROVIDE THE FITTING WITH A HANG SURE SUSPENSION KIT	RUST COPPER	LUMEN 8 BESPOKE DRY DOCK L16	E
L17	22W 4000K LED	RECESSED DOWNLIGHT C/W REMOTE DRIVER	WHITE TRIM	GAMMA ILLUMINATION COBALT 1441-4K-22W	A
L18	22W 4000K LED	RECESSED DOWNLIGHT C/W REMOTE DRIVER	BLACK	GAMMA ILLUMINATION COBALT 1441-4K-22W	A
L19	3000K LED	CUSTOM DECORATIVE BAR COUNTER PENDANT C/W INTEGRAL LED CHIP SET AND REMOTE DALI DIMMABLE DRIVER.	RUST COPPER	LUMEN 8 BESPOKE DRY DOCK L19	E
L20	3000K LED	AMENITY RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE	GAMMA ILLUMINATION MYLO 1004-3K-13W	A
L21	3W 3000K LED	RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER IT IS ACCEPTABLE TO SUPPLY MULTIPLE FITTINGS FROM A SUITABLE SIZED SINGLE DRIVER	SILVER	GAMMA ILLUMINATION 1108	A
L22	0.5w 2200K FANCY ROUND CLEAR	SUSPENDED 24V AV FESTOON LAMP SYSTEM C/W REMOTE TRANSFORMERS AS REQUIRED 500MM LAMP SPACING PROVIDE A STAINLESS STEEL WIRE SUPPORT SYSTEM	BLACK CABLE & BASES	FIRE FLY FC1-50-BL	B
L23	3000K 8W LED	GARDEN SPIKE LIGHT. IP65, PROVIDE THE L23 FITTINGS WITH A COMMON DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION.	BLACK	GAMMA ILLUMINATION 1373-FL-3K-8W-24V	F



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH					
ELECTRICAL EQUIPMENT SCHEDULE					C2864a-0002(J).xls
REVISION J - 28 MAY 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L24	3.9W 3000K LED	FLUSH RECESSED WALL LIGHT CENTRED 300 AFFL. PROVIDE THE L24 FITTINGS WITH A COMMON DALI DIMMABLE POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION.	BLACK	GAMMA ILLUMINATION DUEX 4130-3K-24V	A
L25	3000K LED	CUSTOM SURFACE MOUNTED DECORATIVE BUNKER C/W INTEGRAL LED CHIP SET AND REMOTE DALI DIMMABLE DRIVER.	RUST COPPER	LUMEN 8 BESPOKE DRY DOCK L25	E
L26	2 X 90W COOL WHITE LED	9m HIGH POLE C/W ENGINEER CERTIFIED FOOTING AND A CAR PARK LIGHT 15 DEG TILT	BLACK FITTING & POLE	2 X SAL COMMERCIAL OCS9040NA45	C
L27	2 X 30W COOL WHITE LED	9m HIGH POLE C/W ENGINEER CERTIFIED FOOTING AND A CAR PARK LIGHT 15 DEG TILT	BLACK FITTING & POLE	2 X SAL COMMERCIAL OCS3040NA75	C
L28	2 X 90W COOL WHITE LED	7.8m HIGH POLE C/W A CAR PARK LIGHT MOUNTED ON A ENGINEER CERTIFIED 1200 HIGH 600 DIA REINFORCED CONCRETE BOLLARD / FOOTING. FITTING MOUNTED AT 9m. 15 DEG TILT	BLACK FITTING & POLE	2 X SAL COMMERCIAL OCS9040NA45	C
L29	2 X 30W COOL WHITE LED	7.8m HIGH POLE C/W A CAR PARK LIGHT MOUNTED ON A ENGINEER CERTIFIED 1200 HIGH 600 DIA REINFORCED CONCRETE BOLLARD / FOOTING. FITTING MOUNTED AT 9m. 15 DEG TILT	BLACK FITTING & POLE	2 X SAL COMMERCIAL OCS3040NA75	C
L30	100W COOL WHITE LED	ADJUSTABLE FLOOD LIGHT C/W INTEGRAL DRIVER MOUNTED ON THE BUILDING AS INDICATED.	BLACK	SAL COMMERCIAL FCB10050NAS1	C
L31	2.4W 2700K LED	FLOOR MOUNTED UNDERWATER UP LIGHT C/W 31 DEG BEAM AND A REMOTE DALI DIMMABLE DRIVER. IT IS ACCEPTABLE TO SUPPLY MULTIPLE L31 FITTINGS FROM A SINGLE SUITABLY SIZED DRIVER. LOCATE THE DRIVER IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DRAWINGS.	STAINLESS STEEL	EQUAL TO MODULAR PARTNERS LIGHT GRAPHIX LD242A-700 LW27-MB-DALI	D
L32	3000K LED	CUSTOM DECORATIVE WALL BRACKET PENDANT C/W INTEGRAL LED CHIP SET AND REMOTE DALI DIMMABLE DRIVER.	RUST COPPER	LUMEN 8 BESPOKE DRY DOCK L32	E
L33	44W 3000K LED	WALL MOUNTED WIDE BEAM UP DOWN LIGHT C/W INTEGRAL DALI DIMMABLE DRIVER. CONFIRM THE MOUNTING HEIGHT ON SITE WITH THE ARCHITECT	BLACK	GAMMA ILLUMINATION 1350-VWFL-3K-44W	H
BOTTLE SHOP CABLE TRAY		PROVIDE A BLACK PERFORATED CABLE TRAY SYSTEM SIZED AS PER THE DRAWING. PROVIDE SECURITY AND COMMUNICATIONS CABLING CHANNELS AS PER THE CABLE TRAY SECTIONS. MOUNT THE TRACK, EMERGENCY LIGHTING AND COMMUNICATIONS OUTLETS ON THE UNDERSIDE OF THE CABLE TRAY. ALL COMPONENTS FIXED TO THE CABLE TRAY ARE TO BE BLACK.			B



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075


Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH		C2864a-0002(J).xls			
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION J - 28 MAY 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
	BOTTLE SHOP CABLE TRAY TRACK LIGHTING	3 CHANNEL TRACK MOUNTED ON THE UNDERSIDE OF THE CABLE TRAY CIRCUIT EACH CHANNEL AS PER THE DRAWING. PROVIDE A FITTING FOR EACH 750MM OF TRACK. DISTRIBUTE THE FITTINGS EVENLY ACROSS THE THREE CHANNELS CONFIRM THE FITTING POSITIONS AND AIMING ON SITE WITH THE ARCHITECT	BLACK TRACK BLACK FITTINGS	GAMMA ILLUMINATION 25 SERIES TRACK 1115-VWFL-3K-14W FITTINGS	B
S1	12W/M 3000K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE ABOVE THE BAR / DINING ROOM WALL PELMET AS PER THE ARCHITECTURAL DETAIL PROVIDE REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS	WHITE	NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER	E
S2	12W/M 3000K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE ABOVE THE GAMING ROOM CEILING PELMET AS PER THE ARCHITECTURAL DETAIL PROVIDE REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER	E
S3	12W/M 3000K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE ABOVE THE TAB ROOM CEILING PELMET AS PER THE ARCHITECTURAL DETAIL PROVIDE REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER	E
S4	12W/M 3000K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE ABOVE THE ENTRY CEILING PELMET AS PER THE ARCHITECTURAL DETAIL PROVIDE REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER	E
S5	12W/M 3000K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE WITHIN THE ENTRY PORTAL AS PER THE ARCHITECTURAL DETAIL THE S5 IS TO RISE VERTICALLY FROM THE GROUND TO THE HEAD OF THE PORTAL ACROSS THE PORTAL THEN DOWN TO THE GROUND. PROVIDE REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER	E



C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH						C2864a-0002(J).xls
ELECTRICAL EQUIPMENT SCHEDULE						
REVISION J - 28 MAY 2026						
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK						
www.edg.net.au/Links/Lighting.htm						
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV	
S6	12W/M 3000K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE WITHIN THE GAMING PORTAL AS PER THE ARCHITECTURAL DETAIL. THE S5 IS TO RISE VERTICALLY FROM THE GROUND TO THE HEAD OF THE PORTAL ACROSS THE PORTAL THEN DOWN TO THE GROUND. PROVIDE REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER	E	
S7	12W/M 3000K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE UNDER THE SEAT AS PER THE ARCHITECTURAL DETAIL. PROVIDE REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER	E	
S8	12W/M 3000K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE UNDER THE BAR COUNTER PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER	E	
S9	12W/M 3000K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE UNDER THE EXTERNAL SEAT / STAIR AS PER THE ARCHITECTURAL DETAIL. PROVIDE REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER	E	
S10	A SINGLE HORIZONTAL RUN OF LED STRIP LIGHT 3000K WHITE LEDS AT 12MM SPACING WITH REMOTE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS. MOUNT THE LED STRIP UNDER THE OVERHEAD CUPBOARDS HARD AGAINST THE SPLASHBACK AS PER THE ARCHITECTURAL JOINERY DETAILS. THE SUPPLIER IS TO CUT / JOIN THE LED STRIPS TO SUIT THE SITE DIMENSIONS. DO NOT CUT THE LED STRIPS ON SITE. SCREW FIX THE ALUMINIUM SUPPORT IN PLACE. SUPPLY / SWITCH THE S10 WITH THE ASSOCIATED ROOMS CEILING LIGHTING.			NEON PRODUCTS AUSTRALIA LF-DFB- WW-300-12 + PR- LIN172153-F	G	
S11	12W/M 3000K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE ABOVE THE GAMING ROOM CEILING PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER	E	



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH					C2864a-0002(J).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION J - 28 MAY 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S12		A SINGLE HORIZONTAL RUN OF LED STRIP LIGHT 3000K WHITE LEDS AT 12MM SPACING PER SHELF WITH REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS. RECESS THE LED STRIP INTO THE REAR BAR DISPLAY SHELVING AS PER THE ARCHITECTURAL JOINERY DETAILS REFER TO THE ELEVATIONS FOR THE EXTENT AND QUANTITY. THE SUPPLIER IS TO CUT / JOIN THE LED STRIPS TO SUIT THE SITE DIMENSIONS. DO NOT CUT THE LED STRIPS ON SITE SCREW FIX THE ALUMINIUM SUPPORT IN PLACE.		NEON PRODUCTS AUSTRALIA LF-DFB-WW-300-12 + PR-LIN172153-F	G
S13		TWO HORIZONTAL RUN OF LED STRIP LIGHT 3000K WHITE LEDS AT 12MM SPACING PER SHELF WITH REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS. RECESS THE LED STRIP INTO THE REAR BAR DISPLAY SHELVING AS PER THE ARCHITECTURAL JOINERY DETAILS REFER TO THE ELEVATIONS FOR THE EXTENT AND QUANTITY. THE SUPPLIER IS TO CUT / JOIN THE LED STRIPS TO SUIT THE SITE DIMENSIONS. DO NOT CUT THE LED STRIPS ON SITE SCREW FIX THE ALUMINIUM SUPPORT IN PLACE.		NEON PRODUCTS AUSTRALIA LF-DFB-WW-300-12 + PR-LIN172153-F	G
S14		A SINGLE HORIZONTAL RUN OF LED STRIP LIGHT 3000K WHITE LEDS WITH REMOTE DALI DIMMABLE CONTROL GEAR LOCATED IN A CONCEALED ACCESSIBLE POSITION INDICATED ON THE AS CONSTRUCTED DOCUMENTS. MOUNT THE LED STRIP ON TOP OF THE TIMBER TO ILLUMINATE UPWARDS. THE SUPPLIER IS TO CUT / JOIN THE LED STRIPS TO SUIT THE SITE DIMENSIONS. DO NOT CUT THE LED STRIPS ON SITE SCREW FIX THE ALUMINIUM SUPPORT IN PLACE.		NEON PRODUCTS AUSTRALIA LF-INNF24120T30-OA38 + PR-LIN172153-F	G
HEATER (H1)		NO LONGER REQUIRED			J
HEATER (H2)		WALL MOUNTED 2300w AREA HEATER LOCATED AT 2500 AFFL.	BLACK HEATER AND MOUNTING	BROMIC PLATINUM SMART HEAT ELECTRIC MARINE 2620251	J
HEATER (H3)		CEILING MOUNTED 2300w AREA HEATER. CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT.	BLACK HEATER AND MOUNTING	BROMIC PLATINUM SMART HEAT ELECTRIC MARINE 2620251	J
HEATER CONTROLLER (HC)		NO LONGER REQUIRED			J
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D80 - C90-D80.	WHITE	CLEVERTRONICS CLIFE-PRO	E
E2	LED	EMERGENCY LIGHT: SURFACE MOUNTED ON THE UNDERSIDE OF THE TABLE TRAY SYSTEM NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D80 - C90-D80.	BLACK	CLEVERTRONICS CLIFE-PRO- SM-BLK	E



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH					C2864a-0002(J).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION J - 28 MAY 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
E3		NOT USED			B
E4	LED	EMERGENCY LIGHT: SURFACE MOUNTED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D80 - C90-D80.	BLACK	CLEVERTRONICS CLIFE-PRO- SM-BLK	E
E5	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D80 - C90-D80.	BLACK	CLEVERTRONICS CLIFE-PRO- BLK	E
E6	LED	WHITE EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	WHITE	CLEVERTRONICS LUB PRO SM	A
EX	LED	BLACK EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER.	BLACK	CLEVERTRONICS LUB PRO SM BLK	E
EMERGENCY PACK		LIGHT FITTINGS THAT ARE DESIGNATED AS BEING PROVIDED WITH AN EMERGENCY PACK ARE TO BE PROVIDED WITH AN INTEGRAL AS2293 EMERGENCY PACK. THE FITTINGS ARE TO BE NON MAINTAINED WITH ALL LAMPS SWITCHED AS PER THE LIGHTING CONTROL FOR THAT SPACE UNLESS NOTED OTHERWISE. REFER TO THE SPECIFICATION FOR FURTHER DETAILS OF THE CONFIGURATION AND SWITCHING OF EMERGENCY LIGHTS.			A
CHANNEL x		CONTROL CHANNEL WITH A NUMERICAL REFERENCE. REFER TO THE POWER AND LIGHTING CONTROL SCHEMATIC / SCHEDULE			B
CEILING FAN 1 (F1)		2400 DIA CEILING FAN C/W CUSTOM 250 X 250 TIMBER MOUNTING BLOCK TO ALLOW THE FAN TO BE MOUNTED HORIZONTALLY. CONFIRM THE SUSPENSION HEIGHT OF THE FANS WITH THE ARCHITECT ON SITE. PROVIDE EACH FAN WITH A DEDICATED WIRED WALL MOUNTED ON / OFF / SPEED CONTROLLER	BLACK	EQUAL TO BIG ASS 161-08 C/W WIRED CONTROLLER	B
CEILING FAN 2 (F2)		1500 DIA CEILING FAN C/W CUSTOM 250 X 250 TIMBER MOUNTING BLOCK TO ALLOW THE FAN TO BE MOUNTED HORIZONTALLY. CONFIRM THE SUSPENSION HEIGHT OF THE FANS WITH THE ARCHITECT ON SITE. PROVIDE EACH FAN WITH A DEDICATED WIRED WALL MOUNTED ON / OFF / SPEED CONTROLLER	BLACK	EQUAL TO 1500 DIA CALIBO ALULA C/W WIRED CONTROLLER	B



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH		C2864a-0002(J).xls			
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION J - 28 MAY 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
CEILING FAN CONTROLLER (FC)		DEDICATED WIRED 1000AFFL WALL MOUNTED ON / OFF / SPEED CONTROLLER FOR EACH CEILING FAN PROVIDE WRITTEN CONFIRMATION FROM THE FAN MANUFACTURER THE CONTROLLER IS COMPATIBLE WITH THE FAN.			B
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
TWO-WAY LIGHT SWITCH		TWO -WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
LIGHTING CONTROL SWITCH PANEL (SPx)		6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	ALUMINIUM	DYNALITE ANTUMBRA DISPLAY	A
BOTTLE SHOP LIGHTING CONTROL SWITCH PANEL (SPB)		MULTI GANG SWITCH PANEL AS PER THE SP-B DETAIL MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	STAINLESS STEEL	CLIPSAL B SERIES	A
HAND DRYER CONNECTION (HD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND FOR THE HAND DRYER MOUNT THE GPO AS PER THE ARCHITECTURAL DETAIL	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET AUTO DOOR (AD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT THE OUTLETS WITH IN THE AUTO DOOR MULLION SUCH THAT THE FLEX IS NOT VISIBLE	WHITE	CLIPSAL C2000 SERIES	A
AUTO DOOR PUSH BUTTON (PB)		BLANK FACEPLATE C/W RECESSED DEEP WALL BOX AND A CONCEALED 32 DIA CONDUIT FROM THE WALL BOX TO THE AUTO DOOR MOTOR / CONTROLLER MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES FACEPLATE	A
SINGLE POWER OUTLET SUSPENDED (SUS)		SINGLE 10A POWER OUTLET SUSPENDED TO 1600 AFFL UNLESS NOTED OTHERWISE VIA A 3MM STAINLESS STEEL WIRE ROPE.	WHITE	CLIPSAL "56 SERIES" 56SPO310-RW	A
SINGLE 15A POWER OUTLET SUSPENDED (SUS)		SINGLE 15A POWER OUTLET SUSPENDED TO 1600 AFFL UNLESS NOTED OTHERWISE VIA A 3MM STAINLESS STEEL WIRE ROPE.	WHITE	CLIPSAL "56 SERIES" 56SPO315	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH		C2864a-0002(J).xls			
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION J - 28 MAY 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
IP56 SINGLE POWER OUTLET		SINGLE POWER OUTLET IP56 MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	GREY	CLIPSAL 56 SERIES	A
DOUBLE POWER OUTLET (USB)		DOUBLE POWER OUTLET C/W USB CHARGER AND CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT ABOVE BENCH U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES + 30USBCM MECH	A
IP56 DOUBLE POWER OUTLET		DOUBLE POWER OUTLET IP56 MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	GREY	CLIPSAL 56 SERIES	A
WEATHERPROOF POWER OUTLET (WP)		IP54 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING C/W COVER FLAP OVER SOCKET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 10A U.N.O.	GREY	CLIPSAL WSC227/1-RG	A
15A WEATHERPROOF POWER OUTLET (WP 15A)		IP54 WEATHERPROOF 20A SINGLE POWER OUTLET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 20A U.N.O.	GREY	CLIPSAL WSC227/1/15-RG	A
20A WEATHERPROOF POWER OUTLET (WP 20A)		IP66 WEATHERPROOF 20A SINGLE POWER OUTLET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 20A U.N.O.	GREY	CLIPSAL 56 SERIES	A
SPECIAL PURPOSE OUTLET		SPECIAL PURPOSE OUTLET TYPE AS NOTED. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.			A
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
THREE-PHASE ISOLATOR RSD		THREE-PHASE ISOLATOR. MOUNT AT HIGH LEVEL ADJACENT THE ROLLER SHUTTER DOOR CONTROLLER / MOTOR. COORDINATE THE POSITION ON SITE WITH THE ROLLER SHUTTER DOOR SUPPLIER CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
DOUBLE POWER OUTLET FLOOR MOUNTED (FLOOR)		SURFACE MOUNTED FLOOR BOX C/W A WHITE DOUBLE GPO POWER POINT SOCKET AND A BLANK FACEPLATE ON THE OTHER SIDE.	STAINLESS STEEL FLOOR BOX WHITE OUTLETS	ELECTRIC CABLE DUCT SYSTEMS AFB20 - 4C-SKU040.000.0117 AND CLIPSAL C2000 OUTLET	C



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH					C2864a-0002(J).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION J - 28 MAY 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE GPO / ISOLATORS ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
TIMBER POLE		PROVIDE A DECORATIVE 150 DIA 4000 HIGH TIMBER POLE C/W A CONCRETE FOOTING AND GALVANIZED MOUNTING BRACKET SUCH THAT THE TIMBER IS ABOVE THE GROUND. CONFIRM THE TIMBER TYPE AND FINISH WITH THE ARCHITECT			C
INTERCOM CALL STATION (ICS)		PROVIDE AN IP66 WALL MOUNTED FLUSH RECESSED INTERCOM CALL STATION TO CALL THE INTERCOM HANDSET. SUBMIT DETAILS OF THE INTERCOM SYSTEM FOR APPROVAL			C
INTERCOM HANDSET (IHS)		WALL MOUNTED INTERCOM HANDSET TO ANSWER THE CALL STATION. PROVIDE ALL NECESSARY POWER SUPPLIES LOCATED IN AN ACCESSIBLE CONCEALED POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.			C
SECURITY EQUIPMENT		SECURITY EQUIPMENT BY THE SECURITY CONTRACTOR.			C
DB-1		DISTRIBUTION BOARD DB-1 AS PER THE DB-1 SCHEDULE, POWER SCHEMATICS AND THE SPECIFICATION. PROVIDE A SHOP DRAWING OF DB-1 FOR APPROVAL.			A
DB-2		DISTRIBUTION BOARD DB-2 AS PER THE DB-2 SCHEDULE, POWER SCHEMATICS AND THE SPECIFICATION. PROVIDE A SHOP DRAWING OF DB-2 FOR APPROVAL.			A
DB-B		DISTRIBUTION BOARD DB-B AS PER THE DB-B SCHEDULE, POWER SCHEMATICS AND THE SPECIFICATION. PROVIDE A SHOP DRAWING OF DB-B FOR APPROVAL.			A
MSB		MAIN SWITCHBOARD AS PER THE POWER SCHEMATIC AND THE SPECIFICATION. PROVIDE A SHOP DRAWING OF THE MAIN SWITCHBOARD FOR APPROVAL.			A
MSSB-H		HOTEL MECHANICAL SERVICES SWITCHBOARD PROVIDED BY THE MECHANICAL SUB CONTRACTOR. COORDINATE THE SUBMAIN CONNECTION WITH THE MECHANICAL SUB CONTRACTOR ON SITE.			A
MSSB-B		BOTTLE SHOP MECHANICAL SERVICES SWITCHBOARD PROVIDED BY THE MECHANICAL SUB CONTRACTOR. COORDINATE THE SUBMAIN CONNECTION WITH THE MECHANICAL SUB CONTRACTOR ON SITE.			B
DB-HR		HOTEL REFRIGERATION SERVICES SWITCHBOARD PROVIDED BY THE REFRIGERATION SUB CONTRACTOR. COORDINATE THE SUBMAIN CONNECTION WITH THE REFRIGERATION SUB CONTRACTOR ON SITE.			B
DB-BR		BOTTLE SHOP REFRIGERATION SERVICES SWITCHBOARD PROVIDED BY THE MECHANICAL SUB CONTRACTOR. COORDINATE THE SUBMAIN CONNECTION WITH THE MECHANICAL SUB CONTRACTOR ON SITE.			A
DB-E1 -E9		EV CHARGER DISTRIBUTION BOARD DB-E AS PER THE SPECIFICATION . PROVIDE A SHOP DRAWING OF DB-E1 TO DB-E9 FOR APPROVAL.			B
GENERATOR CONNECTION CUBICLE (GCC)		PROVIDE THE GENERATOR CONNECTION CUBICAL AS A LOCKABLE EXTERNAL GRADE STAINLESS STEEL HOUSING WALL MOUNTED AT LOW LEVEL. PROVIDE THE CUBICAL WITH PRE DRILLED LINKS TO ALLOW TEMPORARY GENERATOR MAIN TO BE CONNECTED. CONNECT THE PERMANENT GENERATOR MAINS TO THE LINKS. PROVIDE THE CUBICAL WITH FACILITY SO THE DOOR CAN BE CLOSED WITH THE TEMPORARY MAINS CONNECTED. SUBMIT A SHOP DRAWING OF THE CUBICAL FOR APPROVAL.			A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH		C2864a-0002(J).xls			
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION J - 28 MAY 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
REVENUE METER (M1)		CODE COMPLIANT RETAIL METER INCLUDING ALL ASSOCIATED COMPONENTS INCLUDING THE METERS AND CTS ETC.			B
PRIVATE METER (M2)		PROVIDE A MULTIFUNCTION METER THAT LOGS THE FOLLOWING ACROSS EACH PHASE, DEMANDS , VOLTAGES, POWER FACTORS, AND HARMONICS.			A
MANUAL TRANSFER SWITCH (MTS)		MANUAL ELECTRICAL AND MECHANICAL INTERLOCKED LOAD TRANSFER SWITCH.			A
HOTEL PV INVERTER (INV-H)		5KW IP 66 1 PHASE PV INVERTER C/W 5 YEAR REPLACEMENT WARRANTY CONNECTED TO THE PV PANELS. REFER TO THE NOTES FOR ADDITIONAL REQUIREMENTS. PROVIDE DETAILS OF THE PV SYSTEM AND DESIGN FOR APPROVAL.			C
HOTEL PV PANELS		6W OF PV PANELS C/W GALVANIZED MOUNTING BRACKET. PROVIDE PV PANELS WITH A 10 YEAR PRODUCT WARRANTY AND A 25 YEAR PANEL PERFORMANCE WARRANTY . REFER TO THE NOTES FOR ADDITIONAL REQUIREMENTS.			C
BOTTLE SHOP PV INVERTER (INV-B)		5KW IP 66 1 PHASE PV INVERTER C/W 5 YEAR REPLACEMENT WARRANTY CONNECTED TO THE PV PANELS. REFER TO THE NOTES FOR ADDITIONAL REQUIREMENTS. PROVIDE DETAILS OF THE PV SYSTEM AND DESIGN FOR APPROVAL.			C
BOTTLE SHOP PV PANELS		6W OF PV PANELS C/W GALVANIZED MOUNTING BRACKET. PROVIDE PV PANELS WITH A 10 YEAR PRODUCT WARRANTY AND A 25 YEAR PANEL PERFORMANCE WARRANTY . REFER TO THE NOTES FOR ADDITIONAL REQUIREMENTS.			C
COMMUNICATIONS RACK (H1)		HOTEL IT FREE STANDING 42 RU MINIMUM 800 DEEP 800 WIDE COMMUNICATIONS RACK CR-1 PROVIDE A SHOP DRAWING OF THE RACK INCLUDING THE ARRANGEMENT OF EQUIPMENT PROVIDED WITHIN IT AS PART OF THE CONTRACT FOR APPROVAL. PROVIDE THE RACK WITH THE REQUIRED CAT 6 PATCH PANELS, CABLE MANAGEMENT AS PER THE SPECIFICATION. PROVIDE THE RACK WITH CASTERS. REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS.		4 CABLING SKU 002.001.4280	A
COMMUNICATIONS RACK (H2)		HOTEL GAMING FREE STANDING 42 RU MINIMUM 600 DEEP 600 WIDE COMMUNICATIONS RACK CR-2 PROVIDE A SHOP DRAWING OF THE RACK INCLUDING THE ARRANGEMENT OF EQUIPMENT PROVIDED WITHIN IT AS PART OF THE CONTRACT FOR APPROVAL. PROVIDE THE RACK WITH THE REQUIRED CAT 6 PATCH PANELS, CABLE MANAGEMENT AS PER THE SPECIFICATION. PROVIDE THE RACK WITH CASTERS. REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS.		4 CABLING SKU 002.001.4280	A
COMMUNICATIONS RACK (H3)		HOTEL AV SECURITY FREE STANDING 42 RU MINIMUM 600 DEEP 600 WIDE RACK CR-3 PROVIDE A SHOP DRAWING OF THE RACK . PROVIDE THE RACK WITH CASTERS. REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS.		4 CABLING SKU 002.001.4280	A
COMMUNICATIONS RACK (H4)		HOTEL AV SECURITY FREE STANDING 42 RU MINIMUM 600 DEEP 600 WIDE RACK CR-4 PROVIDE A SHOP DRAWING OF THE RACK . PROVIDE THE RACK WITH CASTERS. REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS.		4 CABLING SKU 002.001.4280	A
COMMUNICATIONS RACK (CR-B)		BOTTLE SHOP COMMUNICATIONS AV SECURITY WALL MOUNTED HINGED 18 RU MINIMUM 600 DEEP 600 WIDE RACK CR-B PROVIDE A SHOP DRAWING OF THE RACK . REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS.		4 CABLING SKU 002.001.4280	A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH		C2864a-0002(J).xls			
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION J - 28 MAY 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
COMMUNICATIONS OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 PATCH PANELS IN RACK CR-1 VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL UNLESS NOTED OTHERWISE	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
CAT 6 GAMING OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 DEDICATED GAMING PATCH PANELS IN RACK CR-2 VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL UNLESS NOTED OTHERWISE	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
RECESS KIT (RK)		VERTICALLY ORIENTATED WALL BOX TO ALLOW THE OUTLET TO BE RECESSED WITHIN THE WALL CAVITY	WHITE	REPELEC RECWP1WH	B
GAMING FIBRE (GF)		INSTALL DUPLEX FIBRE OPTIC CABLE BETWEEN THE POKER MACHINE BASES AND FROM THE POKER MACHINE BASES BACK TO RACK CR-2 AS INDICATED. THE DUPLEX FIBRE OPTIC CABLE WILL BE SUPPLIED AND TERMINATED BY OTHERS.			A
NBN PREMISE CONNECTION DEVICE (PCD)		NBN COMPLIANT PREMISES CONNECTION DEVICE TO BE CONNECTED TO THE NTD VIA AN NBN COMPLIANT DROP CONDUIT. CONNECT THE PCD TO THE TELSTRA PIT VIA AN NBN COMPLIANT LEAD-IN CONDUIT.			A
NBN NETWORK TERMINATION UNIT (NTD)		NBN COMPLIANT NETWORK TERMINATION UNIT TO BE PROVIDED IN ACCORDANCE WITH THE NBN REQUIREMENTS			A
RISER		PROVIDE THE RISER AS A BLACK 2 CHANNEL 150 X 75 PER CHANNEL ALUMINIUM DUCT WITH A SCREW FIXED REMOVABLE LID WALL MOUNTED FROM THE FLOOR TO THE CEILING SPACE ABOVE. PROVIDE DETAILS OF THE PROPOSED RISER FOR APPROVAL			A
PIT P1		PROVIDE A REINFORCED MASONRY INSITU PIT / TRENCH BELOW MSB FOR THE FULL LENGTH OF THE MSB AS PER THE MSB SECTION DETAIL. PROVIDE AS PART OF THE ELECTRICAL WORKS THE SWITCHBOARD AND LID SUPPORT SYSTEM AND THE TRENCH LIDS. PROVIDE THE TRENCH LIDS AND STRUCTURAL SUPPORT SYSTEM AS HOT DIPPED GALVANISED STEEL. PROVIDE THE TRENCH LIDS WITH LIFTING HOLES CHECKER PLATE R10 ANTI SLIP PATTERNING WITH EACH PART NO HEAVIER THAN 20 kg. FIX THE LIDS IN PLACE SUCH THAT A TOOL IS REQUIRED TO REMOVE THEM. PROVIDE THE TRENCH WITH AN AUTOMATIC SUMP PUMP TO DRAIN TO THE STORMWATER SYSTEM. PROVIDE CABLE SUPPORTS WITHIN THE TRENCH TO ENSURE THAT THERE ARE NO CABLES WITHIN 50MM OF THE TRENCH FLOOR.			A
PIT P2		900 X 900 CLEAR INTERNAL X 1000 DEEP INSITU POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C STEEL LID WITH A SLIP RESISTANCE OF R10 SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL.			A
PIT P3		900 X 900 CLEAR INTERNAL X 1000 DEEP INSITU POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C STEEL LID WITH A SLIP RESISTANCE OF R10 SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL.			A
PIT P4		600 X 600 CLEAR INTERNAL X 700 DEEP INSITU POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C STEEL LID WITH A SLIP RESISTANCE OF R10 SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL.			A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH

C2864a-0002(J).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION J - 28 MAY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
PIT C1		600 X 600 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C STEEL LID WITH A SLIP RESISTANCE OF R10 SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL.			A
PIT C2		450 X 450 CLEAR INTERNAL X 700 DEEP PLASTIC COMMUNICATIONS PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C INFILL LID SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL.			A
TELSTRA / NBN PIT		EXISTING TELSTRA PIT CONFIRM THE POSITION ON SITE			A