



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3040a - BRISBANE TIGERS - STAGE 2

C3040a-0005(A).xls

DISTRIBUTION BOARD DB-A

REVISION A - 05 MAY 2023

							REV
ADD THE FOLLOWING CIRCUITS TO THE EXISTING DISTRIBUTION BOARD DB-A INCORPORATED IN THE EXISTING MSB.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P1						EXISTING	A
P2						EXISTING	A
P3						EXISTING	A
P4						EXISTING	A
P5						EXISTING	A
P6	3	80		25.0		EXISTING	A
P7	1	20	RCD	2.5	TICKET OFFICE	GPO	A
P8	1	20	RCD	2.5	TICKET OFFICE	GPO	A
L1	1	20	RCD A1	2.5	ENTRY GATE	SIGN	A
L2	1	20	RCD A2	2.5	PATHWAY	LIGHTING	A
L3	1	20	RCD A	2.5	CARPARK	LIGHTING	A
L4	1	20	RCD A4	2.5	CARPARK	LIGHTING	A
L5						EXISTING	A
L6						EXISTING	A
L7						EXISTING	A
L8						EXISTING	A
L9						EXISTING	A
L10	1	20	RCD	2.5	TICKET OFFICE	LIGHTS	A