



C3040a - BRISBANE TIGERS - STAGE 2

C3040a-0008(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 11 MAY 2023

MISCELLANEOUS EQUIPMENT					REV
ITEM	DESCRIPTION				
SPD1	6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
CONTROL MODULE 1					A
TYPE: DYNALITE DDRC1220FRGL					A
DESCRIPTION 12CH 20A FEED THROUGH RELAYS C/W CONTACTORS AS REQUIRED					A
LOCATION DIN RAIL MOUNTED IN A DB-A					A
BUS: A					A
CHANNEL	CONTROL	DESCRIPTION			
		LOCATION	CIRCUITS	USE	
A1	SWITCH	CARPARK ENTRY	DB-A - L1	SIGN	A
A2	SWITCH	CARPARK	DB-A - L2	L13, L9	A
A3	SWITCH	ENTRY	DB-A - L3	L22 L13 L2	B
A4	SWITCH	CARPARK	DB-A - L4	L13	B
A5	SWITCH	CARPARK	DB-A - L5	L13	A
					A
					A
					A
					A
					A
CONTROL MODULE 2					A
TYPE: DYNALITE DDRC1220FRGL					A
DESCRIPTION 12CH 20A FEED THROUGH RELAYS C/W CONTACTORS AS REQUIRED					A
LOCATION DIN RAIL MOUNTED IN DB-D					A
BUS: A					A
CHANNEL	CONTROL	DESCRIPTION			
		LOCATION	CIRCUITS	USE	
D1	SWITCH	CARPARK	DB-D - L3	L13	A
D2					B
D3					B
D4	SWITCH	DECK	DB-D - L2	L4	A
D5					B