

NOTES:

- 1. FLOOD LEVEL RL 3.4 AHD.
- 2. PADMOUNT SUBSTATION RL 4.0 AHD.
- 3. ROAD RL 2.5 AHD.
- 4. FOR ALL ENERGEX RELATED CONSTRUCTION QUERIES THE ELECTRICAL DESIGN GROUP ON 0418 893 338 IS THE FIRST POINT OF CALL.
- 5. THE BUILDING WITHIN 4m OF THE PADMOUNT SUBSTATION IS PROTECTED BY A FRL 120/120/120 BARRIER.
- 6. THERE ARE NO HYDRANTS WITHIN 0m OF THE PADMOUNT SUBSTATION AS PER THE REQUIREMENTS OF AS2419.1.
- 7. THERE ARE NO TELSTRA / NBN PITS OR PILLARS WITHIN 2m OF THE PADMOUNT SUBSTATION.
- 8. THE GENERATOR AND FUEL TANK ARE TO BE INSTALLED IN ACCORDANCE WITH AS 1940.
- 9. THE SUBSTATION SITE LOCATION COMPLIES WITH THE HAZARDOUS AREA CLEARANCE REQUIREMENTS OF AS/NZS1940.
- 10. THERE ARE NO GAS SERVICES WITHIN 20M OF THE PADMOUNT SUBSTATION SITE AS PER THE REQUIREMENTS OF AS/NZS 5601.1.
- 11. THE PADMOUNT SUBSTATION IS NOT LOCATED WITHIN 20M OF A SWIMMING POOL. 12. CIVIL RPEQ CERTIFICATION (FORM 15) WILL BE PROVIDED FOR THE DESIGN OF ALL RETAINING WALLS.
- 13. CIVIL RPEQ CERTIFICATION (FORM 16) WILL BE PROVIDED TO CERTIFY ALL CIVIL CONSTRUCTION WORKS PROVIDED BY THE CUSTOMER.
- 14. THE ELECTRICAL PLANT STRUCTURE AND COMPONENTS ARE TO BE INSTALLED IN ACCORDANCE WITH THE NCC BCA 2022.
- 15. THE PADMOUNT SITE MUST BE INSPECTED BY ENERGEX AND HANDED OVER TO ENERGEX AT LEAST 6 WEEKS PRIOR TO THE SUPPLY DATE.





NOTES:

- 1. DO NOT RUN ANY PRIVATE SERVICES CABLING THROUGH THE CULVERT.
- 2. BACKFILLING OF THE PADMOUNT SITE AFTER THE ENERGEX WORKS ARE COMPLETE IS TO BE BY THE CUSTOMER. THE BACKFILLING IS TO BE COMPACTED BEFORE THE FINAL RESTORATION OF THE CONCRETE SURROUND BY THE CUSTOMER AS PER THE ENERGEX SPECIFICATIONS.
- 3. A 2M WIDE SECTION OF THE CONCRETE SURROUND IN FRONT OF THE TRANSFORMER IS TO BE UN-REINFORCED SECTIONED WITH CONSTRUCTION JOINTS FOR EASY REMOVAL.

www.byda.com.au

B CONSTRUCTION

REV: DESCRIPTION:

AS SHOWN

	ENERGEX ACCEPTANCE Venergex
	NAME
	OFFICE
)	SIGNED
	DATE / /
	ENERGEX takes no responsibility for the accuracy of the information provided on this drawing

ELECTRICAL DESIGN GROUP BRISBANE PTY LTD ACN 092 710 793

THE COPYRIGHT OF THIS DRAWING REMAINS THE PROPERTY OF THE ELECTRICAL DESIGN GROUP. USE FIGURED DIMENSIONS IN PREFERENCE TO SCALE.

VERIFIED ONSITE.

CULVERT INSPECTION REQUIRED BEFORE TRANSFORMER IS DELIVERED - 5 BUSINESS DAYS PRIOR NOTICE NEEDED.

ELECTRICAL DESIGN GROUP CONSULTANTS ELECTRICAL BUILDING SERVICES

GOLD COAST

EARTHING ARRANGEMENTS

SCALE 1: 50

BRISBANE

P.O.Box 15, Sherwood Q.4075

Email: brisbane@edg.net.au

Phone: (07) 3278 4375

CURRUMBIN WILDLIFE SANCTUARY SITE MSB

28 TOMEWIN STREET, CURRUMBIN, QUEENSLAND

ELECTRICAL SERVICES ENERGEX REQUIREMENTS

C3112a E07

REVISION: B

18/01/2024

DATE:

TRADING AS: **ELECTRICAL DESIGN GROUP** EMAIL: ALL DIMENSIONS TO BE TRANSFORMER WILL NOT BE ENERGISED UNTIL ALL REQUIREMENTS ARE MET