



NOTES:

1. ALLOW TO EXTEND EXISTING LOUVERS WIRING TO NEW CONNECTION CONTROL BOX MOUNTED TO POLE.
2. ALLOW TO INSPECT AND IF NECESSARY REWIRE EXISTING HI-BAY LIGHTING SYSTEM TO WP JUNCTION BOX MOUNTED ON POLE.
3. PROVIDE CONNECTION POINT ON POLE FOR EXISTING LIGHTING AND LOUVERS. ENCLOSURE TO BE IP RATED.
4. INSTALL CONDUIT IN GROUND BETWEEN POST AND LOWER GROUND LSP OUTSIDE LIFT LOBBY FOR EXISTING LIGHTING AND LOUVERS.

THE COPYRIGHT OF THIS DRAWING REMAINS THE PROPERTY OF THE ELECTRICAL DESIGN GROUP.
 USE FIGURED DIMENSIONS IN PREFERENCE TO SCALE.
 ALL DIMENSIONS TO BE VERIFIED ONSITE.

C	INFORMATION	11/12/2023
REV:	DESCRIPTION:	DATE:

ELECTRICAL DESIGN GROUP
 ELECTRICAL BUILDING SERVICES CONSULTANTS

BRISBANE: P.O. Box 15 Sherwood Qld 4075
 Phone: (07) 3278 4375
 Email: brisbane@edg.net.au
 Web: www.edg.net.au

ELECTRICAL DESIGN GROUP BRISBANE PTY LTD
 ACN 092 710 793

TRADING AS:
 ELECTRICAL DESIGN GROUP

PROJECT:
**LOURDES HILL COLLEGE
 STAGE 1**

SITE ADDRESS:
 86 HAWTHORNE ROAD,
 HAWTHORNE, QUEENSLAND

SCALE: 1:100 SHEET SIZE: AT A1

DRAWING TITLE:
**ELECTRICAL SERVICES
 STAGE 1A GROUND LEVEL
 REFLECTED CEILING PLAN**

PROJECT NO. DRAWING NO. REVISION:
C3134a E08 C