

ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222


Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3144a - ST JOHNS ANGLICAN COLLEGE, FOREST LAKE - HEALTH & WELLBEING CENTRE C3144a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 20 OCTOBER 2023

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1	40W WHITE LED	600 X 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN THE CEILING T BAR	WHITE TRIM	GAMMA ILLUMINATION PHANTOM 884502-4K	A
L2	13W 3000K LED	RECESSED 52 DEG BEAM DOWNLIGHT C/W REMOTE DRIVER	WHITE TRIM	GAMMA ILLUMINATION COBALT 1402-4K-13W	A
L3	A SINGLE HORIZONTAL RUN OF LED STRIP LIGHT 4000K WHITE LEDS AT 12MM SPACING WITH REMOTE CONTROL GEAR. MOUNT THE FITTING HARD AGAINST THE SPLASHBACK UNDER THE OVERHEAD CUPBOARD THE SUPPLIER IS TO CUT / JOIN THE LED STRIPS TO SUIT THE SITE DIMENSIONS. DO NOT CUT THE LED STRIPS ON SITE SCREW FIX THE ALUMINIUM SUPPORT IN PLACE.			NEON PRODUCTS AUSTRALIA LF-DFB-NW-300-12 + PR-LINR-172153-F	A
L4	8W 4000K LED	RECESSED 47 DEG BEAM DOWNLIGHT C/W REMOTE DRIVER	WHITE TRIM	GAMMA ILLUMINATION MYLO 1004-WFL-4K-8W	A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	WHITE	CLEVERTRONICS CLIFE	A
EX	LED	EXIT LIGHT SURFACE MOUNTED MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN AS2293 CLASSIFICATION C0-D3.2 - C90-E2.	WHITE LOGO, GREEN BACKGROUND, WHITE BODY	CLEVERTRONICS LUB PRO SM	A
PRESENCE DETECTOR SWITCH (PD)	ADJUSTABLE FLUSH RECESSED 360 DEGREE TRIPLE PYRO PIR PRESENCE DETECTOR TO OPERATE THE ASSOCIATED LIGHTS FOR A PRE-SET AMOUNT OF TIME. ADJUST THE TIME AND SENSITIVITY ON SITE AS DIRECTED BY THE ENGINEER.		WHITE	CLIPSAL. SELECTION BY THE CONTRACTOR. SUBMIT DETAILS OF THE PROXIMITY DETECTOR SWITCH FOR APPROVAL PRIOR TO ORDERING	A
ONE-WAY SWITCH	ONE-WAY SWITCH MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.		WHITE	CLIPSAL C2000 SERIES FACEPLATE	A
ONE-WAY ARCHITRAVE SWITCH	ONE-WAY ARCHITRAVE SWITCH MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.		WHITE	CLIPSAL C2000 SERIES ARCHITRAVE FACEPLATE	A
SMOKE DETECTOR	AS1670 SMOKE DETECTOR TO BE CONNECTED TO THE FIRE INDICATING PANEL				A
FIRE EVACUATION SPEAKER	FIRE EVACUATION SPEAKER TO BE CONNECTED TO THE FIRE INDICATING PANEL				A




C3144a - ST JOHNS ANGLICAN COLLEGE, FOREST LAKE - HEALTH & WELLBEING CENTRE C3144a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 20 OCTOBER 2023

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SCHOOL BELL SPEAKER		NEW 15W MULTI TAP RECESSED COAXIAL CONE SPEAKER C/E WHITE GRILL CONNECTED TO THE NEW SCHOOL BELL AMPLIFIER			A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET C/W USB CHARGERS		DOUBLE POWER OUTLET C/W DUAL USB A AND USB C CHARGING PORTS CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT ABOVE BENCH U.N.O. RATING 10A U.N.O.	WHITE	CLIPSAL C2000 SERIES	A
HAND DRYER CONNECTION (HD)		20A ISOLATING SWITCH WALL MOUNTED AT 2400mm AFFL AND CONNECTED TO THE HAND DRYER UNIT AS PER DETAIL.	WHITE	CLIPSAL C2000 SERIES	A
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 40A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
RECESS KIT (RK)		VERTICALLY ORIENTATED WALL BOX TO ALLOW THE OUTLET TO BE RECESSED WITHIN THE WALL CAVITY	WHITE	REPELEC RECWP1WH	A
COMMUNICATIONS RACK CR-CG		UPDATE THE RACK AS NECESSARY TO ACCOMMODATE THE COMMUNICATIONS OUTLETS MADE REDUNDANT BY AND THOSE PROVIDED AS PART OF THE NEW WORKS.			A
CAT 6 COMMUNICATIONS OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO COMMUNICATIONS RACK CR-CG TERMINATED ONTO FACILITY PATCH PANELS VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
DB-CG		EXISTING DISTRIBUTION BOARD DB-CG TO BE PROVIDED WITH ADDITIONAL SWITCHGEAR AS NECESSARY TO ACCOMMODATE THE NEW CIRCUITS. REFER TO THE DISTRIBUTION BOARD SCHEDULE FOR THE DETAILS OF THE NEW CIRCUITS. UPDATE THE SWITCHBOARDS SCHEDULE CARD TO REFLECT THE AS BUILT INSTALLATION.			A
SECURITY EQUIPMENT		EXISTING SECURITY EXPANDER PANEL TO BE UPGRADED AS NECESSARY TO ACCOMMODATE THE REVISED / ADDITIONAL DETECTORTS.			A
KEY PAD		RELOCATE THE EXISTING SECURITY KEY PADE			A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3144a - ST JOHNS ANGLICAN COLLEGE, FOREST LAKE - HEALTH & WELLBEING CENTRE C3144a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 20 OCTOBER 2023

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SECURITY INTRUDER DETECTOR		SECURITY INTRUDER DETECTOR TO BE MATCH THE EXISTING			A