



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3234a - 185 SAMFORD ROAD, ENOGGERA
DISTRIBUTION BOARD DB-B (GROUND SOUTH)
REVISION 2 - 01 JUNE 2026

C3234a-0006(2).xls

							REV
FAULT CURRENT:		6KA USING CASCADING		MAIN SWITCH:		250A NON AUTO LOAD BREAK	A
CHASSIS SIZE:		84 POLE POWER 24 POLE LIGHTING		SUPPLIED FROM:		MSB	A
CHASSIS RATING:		250A		SUPPLY CABLE:		1C70AL	1
PHASES:		3					A
PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS. PROVIDE THE DB WITH AN AS2293 EMERGENCY LIGHTING CONTROL SYSTEM TO CONTROL THE ASSOCIATED EMERGENCY LIGHTS. PROVIDE THE DB WITH SURGE PROTECTION. PROVIDE AN ENERGY MONITORING SYSTEM OF THE LIGHTING CHASSIS AND POWER CHASSIS AS PER J9D3 OF THE NCC BCA 2022 THAT COLLATES THE TIME-OF-USE ENERGY DATA TO A SINGLE INTERFACE WHERE IT CAN BE STORED, ANALYSED AND REVIEWED							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5	LEVEL 0	CLEANING MAINT	A
P2	1	20	RCBO	2.5		TV	A
P3	1	20	RCBO	2.5		CLEANING MAINT	A
P4	3	20	RCBO	2.5	LEVEL 0	STORM WATER PUMP	A
P5	1	20	RCBO	2.5	LEVEL 0	IRRIGATION CONTROL	A
P6	1	20	RCBO	2.5	LEVEL 0	IRRIGATION PUMP	A
P7	1	20	RCBO	2.5	LEVEL 1	MAINTENANCE	A
P8	1	20	RCBO	2.5	LEVEL 1	MIST PUMP	A
P9	1	20	RCBO	2.5	LEVEL 1	MIST PUMP	A
P10	1	20	RCBO	2.5	LEVEL 1	JACKING PUMP	A
P11	1	20	RCBO	2.5	LEVEL 1	JACKING PUMP	A
P12	3	20	RCBO	2.5	LEVEL 1	RSD	A
P13	1	20	RCBO	2.5	LEVEL 2	MAINTENANCE	A
P14	1	20	RCBO	2.5	LEVEL 1	CLEANING	A
P15	1	20	RCBO	2.5	LEVEL 1	TASTING	A
P16	1	20	RCBO	2.5	LEVEL 1	DINING	A
P17	1	20	RCBO	2.5	LEVEL 1	TV	A
P18	1	20	RCBO	2.5	LEVEL 1	AMENITY	A
P19	1	20	RCBO	2.5	LEVEL 1	HD	A
P20	1	20	RCBO	2.5	LEVEL 1	HD	A
P21	1	20	RCBO	2.5	LEVEL 1	STAFF GPO	A
P22	1	20	RCBO	2.5	LEVEL 1	HD	A
P23	1	20	RCBO	2.5	LEVEL 1	STAFF APPLIANCES	A
P24	1	20	RCBO	2.5	LEVEL 1	LAUNDRY	A
P25	1	20	RCBO	2.5	LEVEL 1	LAUNDRY	A
P26	1	20	RCBO	2.5	LEVEL 1	OFFICE	A
P27	1	20	RCBO	2.5	LEVEL 1	SECURITY	A
P28	1	20	RCBO	2.5	LEVEL 1	RACK A	A
P29	1	20	RCBO	2.5	LEVEL 1	RACK A	A
P30	1	20	RCBO	2.5	LEVEL 1	RACK B	A
P31	1	20	RCBO	2.5	LEVEL 1	RACK B	A
P32	1	20	RCBO	2.5	LEVEL 1	RACK C	A
P33	1	20	RCBO	2.5	LEVEL 1	RACK C	A
P34	1	20	RCBO	2.5	LEVEL 1	RACK D	A
P35	1	20	RCBO	2.5	LEVEL 1	RACK D	A
P36	1	20	RCBO	2.5	BAR	POS	2
P37	1	20	RCBO	2.5	BAR	BAR GPO	A
P38	1	20	RCBO	2.5	BAR	REF	A
P39	1	20	RCBO	2.5	OFFICE	OFFICE	2
P40	1	20	RCBO	2.5	PREP	GLASS WASHER	2
P41	1	20	RCBO	2.5	PREP	15A GPO	2
P42	1	20	RCBO	2.5	PREP	15A GPO	2
P43	1	20	RCBO	2.5	PREP	HEATER	2
P44	1	20	RCBO	2.5	PREP	HEATER	2
P45	1	20	RCBO	2.5	GARDEN ROOM	PROJECTOR	A
P46	1	20	RCBO	2.5	EXTERNAL	LIFT SUMP ALARM	1
P47	1	20	RCBO	2.5	OFICE	PHOTO COPIER	2

