ELECTRICAL DESIGN GROUP
ELECTRICAL BUILDING SERVICES CONSULTANTS
P.O. Box 15, SHERWOOD Q. 4075
Phone: 0418 893 338
Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3584a - METROPOLE HOTEL, PROSERPINE **C3584a-0002(A).xls**

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 09 NOVEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1	15W 2700K LED	90 DIA RECESSED ADJUSTABLE DOWNLIGHT C/W 60 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1078-WH-15W-XW-60	A
L2	34W 4000K LED	1200 x 300 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PB MOUNTING KIT	WHITE TRIM	GAMMA ILLUMINATION AXIS 1549-4K-34W C/W FLUSH RECESS PB KIT	A
L3	15W 2700K LED	75 DIA RECESSED ADJUSTABLE DOWNLIGHT C/W 60 DEG BEAM REMOTE DALI DIMMABLE DRIVER	BLACK	RAPID LED R1077-BK-15W-XW-60	A
L4	36W LED 4000K	SURFACE MOUNTED IP66 1200 LONG BATTEN C/W INTEGRAL DRIVER	LIGHT GREY	GAMMA STORM 1558-CCT-36	A
L5	12W 2700K LED	90 DIA RECESSED ADJUSTABLE DOWNLIGHT C/W 60 DEG BEAM REMOTE DRIVER	WHITE	RAPID R1078-WH-12W-XW-60	A
L6	15W 2700K LED	90 DIA RECESSED ADJUSTABLE DOWNLIGHT C/W 60 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1078-WH-15W-XW-60	A
L7	9W 2700K LED	90 DIA RECESSED ADJUSTABLE DOWNLIGHT C/W 9 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1078-WH-15W-XW-24	A
L8	15W 2700K LED	75 DIA RECESSED ADJUSTABLE DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	BLACK	RAPID LED R1077-BK-15W-XW-24	A
L9	9W 3000K LED PER FITTING	SURFACE TRACK C/W FITTINGS AS INDICATED PROVIDE EACH TRACK WITH A REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	BLACK	LUMEN 8 NIX 45 TRACK AND SOLIS SON145TK09930 FITTINGS DALI DIMMABLE	A
L10	15W 2700K LED	75 DIA RECESSED ADJUSTABLE DOWNLIGHT C/W 60 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPIDR1078-WH-15W-XW-24	A
L11	15W 2700K LED	90 DIA RECESSED ADJUSTABLE DOWNLIGHT C/W 60 DEG BEAM REMOTE DRIVER	WHITE	RAPID R1078-WH-15W-XW-60	A

ELECTRICAL DESIGN GROUP BRISBANE PTY LTD ACN 092 710 793
TRADING AS – ELECTRICAL DESIGN GROUP ABN 96 092 710 793

ELECTRICAL DESIGN GROUP
ELECTRICAL BUILDING SERVICES CONSULTANTS
P.O. Box 15, SHERWOOD Q. 4075
Phone: 0418 893 338
Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3584a - METROPOLE HOTEL, PROSERPINE **C3584a-0002(A).xls**

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 09 NOVEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
WL1	TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 LED 750 LUMENS +/- 10%	DECORATIVE WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS ALLOW TO INSTALL	TBA	ALLOW A PC SUM OF $250.00 PLUS GST FOR THE SUPPLY OF EACH WL01 FITTING	A
WL2	2 X 22W 3000K LED	2 X IP54 ADJUSTABLE FLOOD LIGHTS C/W INTEGRAL DRIVER MOUNTED ON A 2700 HIGH BLACK SQUARE POLE C/W REINFORCED CONCRETE FOOTING	BLACK	GAMMA ILLUMINATION VIXO 1115SM-VWFL-3K-22W	A
WL3	22W 3000K LED	IP54 ADJUSTABLE FLOOD LIGHT C/W INTEGRAL DRIVER MOUNTED AT HIGH LEVEL ON THE ENTRY STRUCTURE TO ILLUMINATE DOWNWARDS.	BLACK	GAMMA ILLUMINATION VIXO 1115SM-VWFL-3K-22W	A
WL4	22W 3000K LED	IP54 ADJUSTABLE FLOOD LIGHT C/W INTEGRAL DRIVER MOUNTED AT HIGH LEVEL ON THE REAR OF THE LED SCREEN STRUCTURE TO ILLUMINATE DOWNWARDS.	BLACK	GAMMA ILLUMINATION VIXO 1115SM-VWFL-3K-22W	A
WL5	22W 3000K LED	IP54 ADJUSTABLE FLOOD LIGHT C/W INTEGRAL DRIVER MOUNTED AT HIGH LEVEL ON THE BUILDING FAÇADE TO ILLUMINATE DOWNWARDS.	BLACK	GAMMA ILLUMINATION VIXO 1115SM-SP-3K-22W	A
PL1	TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 LED 750 LUMENS +/- 10%	410 DIA X 600 HIGH DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	NATURAL RATTAN SHADE BLACK FRAME	BEACON LIGHTING HAYES 1 LARGE	A
PL2	TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 LED 750 LUMENS +/- 10%	400 DIA X 255 HIGH DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	TAN	FAT SHACK VINTAGE TOURS NORD PENDANT LIGHT WOVEN SHADE WITH CLEAR INNER LINING WOOD BLOCK MOUNT AND BRAIDED SUSPENSION WHITE CEILING MOUNTING PLATE	A
PL3	4 X TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 LED 750 LUMENS +/- 10%	1500 LONG X 350 HIGH DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	MATT BLACK AND GOLD	LIGHTING COLLECTIVE LONG IRON PENDANT	A
PL4	2700K LED	700 DIA DECORATIVE PENDANT C/W REMOTE TRAILING EDGE DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITIONS NOTED ON THE AS CONSTRUCTED DOCUMENTS. . CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	BRUSHED GOLD	ABOUT SPACE HOOP LED 22 X 36 CUSTOM PENDANT	A
PL5	2700K LED	1000 DIA DECORATIVE PENDANT C/W REMOTE TRAILING EDGE DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITIONS NOTED ON THE AS CONSTRUCTED DOCUMENTS. . CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	BRUSHED GOLD	ABOUT SPACE HOOP LED 22 X 36 CUSTOM PENDANT	A

ELECTRICAL DESIGN GROUP
ELECTRICAL BUILDING SERVICES CONSULTANTS
P.O. Box 15, SHERWOOD Q. 4075
Phone: 0418 893 338
Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3584a - METROPOLE HOTEL, PROSERPINE **C3584a-0002(A).xls**

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 09 NOVEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
FS1	1W LED AT 500 CENTRES	FESTOON LIGHTS WITH NEW 24V DC IP65 FESTOON LIGHTING TO BE FIXED TO A 316 STAINLESS STEEL WIRE SUPPORT SYSTEM. SUPPLY THE FESTOON LIGHTS VIA REMOTE DALI DIMMABLE DRIVERS IN A CONCEALED ACCESSIBLE POSITIONS NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE LENGTH AND POSITION ON SITE . PROVIDE THE FESTOON INSTALLATION IN THE BEER GARDEN WITH SCREW PLUGS AND SCREW GATE CARABINES ON THE SUPPORTS SUCH THAT IT CAN BE REMOVED AS PART OF PREPARING FOR A CYCLONE.	BLACK CABLE AND FIXINGS 316 STAINLESS STEEL SUPPORT AND FIXINGS	FIRE FLY FFC-LS-50-24VE27-BK	A
PENDANT HEAT LAMP(HL1)		PENDANT HEAT LAMP	ANTIQUE BRASS	HATCO DL-700-SU PLUS 100W IR LAMP	A
PENDANT HEAT LAMP(HL2)		PENDANT HEAT LAMP	ANTIQUE BRASS	HATCO DL-700-SU PLUS 100W IR LAMP	A
S1	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER WITHIN THE GAMING CURTAIN PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S2	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE GAMING SCREE AS PER THE ARCHITECTURAL GAMING SCREEN DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D80 - C90-D80.	WHITE	CLEVERTRONICS CLIFE-PRO	A
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER.	WHITE	CLEVERTRONICS LUB PRO SM	A

ELECTRICAL DESIGN GROUP BRISBANE PTY LTD ACN 092 710 793
TRADING AS – ELECTRICAL DESIGN GROUP ABN 96 092 710 793

ELECTRICAL DESIGN GROUP
ELECTRICAL BUILDING SERVICES CONSULTANTS
P.O. Box 15, SHERWOOD Q. 4075
Phone: 0418 893 338
Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3584a - METROPOLE HOTEL, PROSERPINE **C3584a-0002(A).xls**

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 09 NOVEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
CHANNEL x		CONTROL CHANNEL WITH A NUMERICAL REFERENCE. REFER TO THE LIGHTING CONTROL SCHEMATIC			A
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
TWO-WAY LIGHT SWITCH		TWO -WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
LIGHTING CONTROL SWITCH PANEL (SPA)		MULTI GANG SWITCH PLATE AS PER THE SP-A SCHEMATIC MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000	A
LIGHTING CONTROL SWITCH PANEL (SPB)		TWO MULTI GANG SWITCH PLATE AS PER THE SP-B SCHEMATIC MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000	A
MANUAL DALI POT DIMMER / LIGHT SWITCH (DALI)		DALI POT C/W INTEGRAL 20 DALI DEVICE POWER SUPPLY . FACTORY SET POWER ON RETURN TO LAST LEVEL.	WHITE	SMARTSCAPE DALI RD20 CLIPSAL C2000	A
MANUAL TRAILING EDGE POT DIMMER / LIGHT SWITCH (TE)		350W UNIVERSAL POT DIMMER C/W INTEGRAL ON / OFF PUSH BUTTON	WHITE	CLIPSAL CL30ERPBDM-WE	A
WALL FAN		400 DIA 40 WATT WHITE OR SILVER WALL MOUNTED IP65 FAN C/W SEALED MOTOR PLASTIC OR GALVANIZED BLADES PLASTIC OR GALVANIZED ENCLOSING GRILL MANUAL ON OFF SWITCH AND MANUAL SPEED CONTROL MOUNT AT HIGH LEVEL AND PLUG INTO THE ADJACENT FAN GPO. SUBMIT DETAILS FOR APPROVAL			A
HAND DRYER CONNECTION (HD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND FOR THE HAND DRYER MOUNT THE GPO AS PER THE ARCHITECTURAL DETAIL	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET AUTO DOOR (AD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT THE OUTLETS WITH IN THE AUTO DOOR MULLION SUCH THAT THE FLEX IS NOT VISIBLE	WHITE	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A

ELECTRICAL DESIGN GROUP BRISBANE PTY LTD ACN 092 710 793
TRADING AS – ELECTRICAL DESIGN GROUP ABN 96 092 710 793

ELECTRICAL DESIGN GROUP
ELECTRICAL BUILDING SERVICES CONSULTANTS
P.O. Box 15, SHERWOOD Q. 4075
Phone: 0418 893 338
Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3584a - METROPOLE HOTEL, PROSERPINE **C3584a-0002(A).xls**

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 09 NOVEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
IP56 SINGLE POWER OUTLET		SINGLE POWER OUTLET IP56 MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	GREY	CLIPSAL 56 SERIES	A
IP56 DOUBLE POWER OUTLET		DOUBLE POWER OUTLET IP56 MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	GREY	CLIPSAL 56 SERIES	A
WEATHERPROOF POWER OUTLET (WP)		IP54 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING C/W COVER FLAP OVER SOCKET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 10A U.N.O.	GREY	CLIPSAL WSC227/1-RG	A
15A WEATHERPROOF POWER OUTLET (WP 15A)		IP54 WEATHERPROOF 20A SINGLE POWER OUTLET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 20A U.N.O.	GREY	CLIPSAL WSC227/1/15-RG	A
20A WEATHERPROOF POWER OUTLET (WP 20A)		IP66 WEATHERPROOF 20A SINGLE POWER OUTLET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 20A U.N.O.	GREY	CLIPSAL 56 SERIES	A
SPECIAL PURPOSE OUTLET		SPECIAL PURPOSE OUTLET TYPE AS NOTED. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.			A
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE GPO / ISOLATORS ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
DB-1		EXISTING DISTRIBUTION BOARD DB-1 TO BE REMOVED. ALL EXISTING DB-1 CIRCUITS THAT REMAIN ARE TO BE RESUPPLIED FROM DB-A WITH NEW SWITCHGEAR.			A
DB-2		EXISTING DISTRIBUTION BOARD DB-2 TO BE REMOVED. ALL EXISTING DB-2 CIRCUITS THAT REMAIN ARE TO BE RESUPPLIED FROM DB-A WITH NEW SWITCHGEAR.			A
DB-3		EXISTING DISTRIBUTION BOARD DB-3 TO BE REMOVED. ALL EXISTING DB-3 CIRCUITS THAT REMAIN ARE TO BE RESUPPLIED FROM DB-B WITH NEW SWITCHGEAR.			A
DB-4		EXISTING DISTRIBUTION BOARD DB-4 TO BE RESUPPLIED FROM DB-C.			A
DB-5		EXISTING DISTRIBUTION BOARD DB-5 TO BE RESUPPLIED FROM DB-D.			A

ELECTRICAL DESIGN GROUP BRISBANE PTY LTD ACN 092 710 793
TRADING AS – ELECTRICAL DESIGN GROUP ABN 96 092 710 793

ELECTRICAL DESIGN GROUP
ELECTRICAL BUILDING SERVICES CONSULTANTS
P.O. Box 15, SHERWOOD Q. 4075
Phone: 0418 893 338
Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3584a - METROPOLE HOTEL, PROSERPINE **C3584a-0002(A).xls**

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 09 NOVEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
DB-6		EXISTING DISTRIBUTION BOARD DB-6 TO BE REMOVED.			A
DB-7		EXISTING DISTRIBUTION BOARD DB-7 TO BE RESUPPLIED FROM DB-D.			A
DB-A		DISTRIBUTION BOARD DB-A AS PER THE DB-B SCHEDULE, POWER SCHEMATICS AND THE NOTES. PROVIDE A SHOP DRAWING OF DB-A FOR APPROVAL.			A
DB-B		DISTRIBUTION BOARD DB-B AS PER THE DB-B SCHEDULE, POWER SCHEMATICS AND THE NOTES. PROVIDE A SHOP DRAWING OF DB-B FOR APPROVAL.			A
DB-C		DISTRIBUTION BOARD DB-C AS PER THE DB-C SCHEDULE, POWER SCHEMATICS AND THE NOTES. PROVIDE A SHOP DRAWING OF DB-C FOR APPROVAL.			A
DB-D		DISTRIBUTION BOARD DB-D INTEGRAL TO THE MSB AS PER THE DB-D SCHEDULE, POWER SCHEMATICS AND THE NOTES.			A
DB-E		DISTRIBUTION BOARD DB-E AS PER THE DB-E SCHEDULE, POWER SCHEMATICS AND THE SPECIFICATION. PROVIDE A SHOP DRAWING OF DB-E FOR APPROVAL.			A
INV1		SOLAR INVERTER 1 BY THE SOLAR CONTRACTOR			A
INV2		SOLAR INVERTER 2 BY THE SOLAR CONTRACTOR			A
MSB		NEW MAIN SWITCHBOARD PER THE POWER SCHEMATICS AND THE NOTES. PROVIDE A SHOP DRAWING OF DB-C FOR APPROVAL.			A
MSB 1		EXISTING MAIN SWITCHBOARD TO BE REMOVED INCLUDING THE EARTHING MEN LINK, RETAIL METERING AUTHORITY LABELS AND ASSOCIATED CONSUMERS MAINS. ARRANGE FOR THE SUPPLY ABOLISHMENT INCLUDING THE AUTHORITY ABOLISHMENT COSTS.			A
MSB 2		EXISTING MAIN SWITCHBOARD TO BE REMOVED INCLUDING THE EARTHING MEN LINK, RETAIL METERING AUTHORITY LABELS AND ASSOCIATED CONSUMERS MAINS. ARRANGE FOR THE SUPPLY ABOLISHMENT INCLUDING THE AUTHORITY ABOLISHMENT COSTS.			A
MSB 3		EXISTING MAIN SWITCHBOARD TO BE REMOVED INCLUDING THE EARTHING MEN LINK, RETAIL METERING AUTHORITY LABELS AND ASSOCIATED CONSUMERS MAINS. ARRANGE FOR THE SUPPLY ABOLISHMENT INCLUDING THE AUTHORITY ABOLISHMENT COSTS.			A
MSB 4		EXISTING MAIN SWITCHBOARD TO BE REMOVED INCLUDING THE EARTHING MEN LINK, RETAIL METERING AUTHORITY LABELS AND ASSOCIATED CONSUMERS MAINS. ARRANGE FOR THE SUPPLY ABOLISHMENT INCLUDING THE AUTHORITY ABOLISHMENT COSTS.			A
METERING TEST BLOCK METER (MTB)		QECM V4 COMPLIANT METERING TEST BLOCK INCLUDING ALL ASSOCIATED COMPONENTS			A
REVENUE METER (KWH)		NEM CODE COMPLIANT CT RETAIL METER INCLUDING ALL ASSOCIATED COMPONENTS			A

ELECTRICAL DESIGN GROUP BRISBANE PTY LTD ACN 092 710 793
TRADING AS – ELECTRICAL DESIGN GROUP ABN 96 092 710 793

ELECTRICAL DESIGN GROUP
ELECTRICAL BUILDING SERVICES CONSULTANTS
P.O. Box 15, SHERWOOD Q. 4075
Phone: 0418 893 338
Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3584a - METROPOLE HOTEL, PROSERPINE **C3584a-0002(A).xls**

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 09 NOVEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
DEMAND METER (MD)		PRIVATE MULTI FUNCTION DEMAND LOGGING METER.			A
GENERATION SIGNALLING DEVICE (GSD)		QECM V4 COMPLIANT GENERATION SIGNALLING DEVICE INCLUDING ALL ASSOCIATED COMPONENTS			A
DEMAND RESPONSE SITE CONTROLLER (DRSC)		QECM V4 COMPLIANT DEMAND RESPONSE SITE CONTROLLER INCLUDING ALL ASSOCIATED COMPONENTS COORDINATE THE CONTROL WITH THE SOLAR CONTRACTOR			A
MANUAL TRANSFER SWITCH (MTS)		MECHANICALLY INTERLOCKED MANUAL TRANSFER SWITCH.			A
SOLAR CONTACTOR 1 (SC1)		SOLAR CONTROL LOAD BREAK CONTACTOR RATED ABOVE THE CIRCUIT BREAKER FAME SIZE			A
SOLAR CONTACTOR 2 (SC2)		SOLAR CONTROL LOAD BREAK CONTACTOR RATED ABOVE THE CIRCUIT BREAKER FAME SIZE			A
COMMUNICATIONS RACK (CR-1)		HOTEL IT FREE STANDING 42 RU MINIMUM 800 DEEP 800 WIDE COMMUNICATIONS RACK CR-1 PROVIDE A SHOP DRAWING OF THE RACK INCLUDING THE ARRANGEMENT OF EQUIPMENT PROVIDED WITHIN IT AS PART OF THE CONTRACT FOR APPROVAL. PROVIDE THE RACK WITH THE REQUIRED CAT 6 PATCH PANELS, CABLE MANAGEMENT AS PER THE SPECIFICATION. PROVIDE THE RACK WITH CASTERS. REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS.		4 CABLING SKU 002.001.4280	A
COMMUNICATIONS RACK (CR-G)		HOTEL GAMING FREE STANDING 42 RU MINIMUM 600 DEEP 600 WIDE COMMUNICATIONS RACK CR-G PROVIDE A SHOP DRAWING OF THE RACK INCLUDING THE ARRANGEMENT OF EQUIPMENT PROVIDED WITHIN IT AS PART OF THE CONTRACT FOR APPROVAL. PROVIDE THE RACK WITH THE REQUIRED CAT 6 PATCH PANELS, CABLE MANAGEMENT AS PER THE SPECIFICATION. PROVIDE THE RACK WITH CASTERS. REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS.		4 CABLING SKU 002.001.4280	A
COMMUNICATIONS OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 PATCH PANELS IN RACK CR-1 VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL UNLESS NOTED OTHERWISE	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
CAT 6 GAMING OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 PATCH PANELS IN RACK CR-G VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL UNLESS NOTED OTHERWISE	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A

ELECTRICAL DESIGN GROUP BRISBANE PTY LTD ACN 092 710 793
TRADING AS – ELECTRICAL DESIGN GROUP ABN 96 092 710 793

ELECTRICAL DESIGN GROUP
ELECTRICAL BUILDING SERVICES CONSULTANTS
P.O. Box 15, SHERWOOD Q. 4075
Phone: 0418 893 338
Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3584a - METROPOLE HOTEL, PROSERPINE **C3584a-0002(A).xls**

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 09 NOVEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
GAMING FIBRE (GF)		INSTALL DUPLEX FIBRE OPTIC CABLE BETWEEN THE POKER MACHINE BASES AND FROM THE POKER MACHINE BASES BACK TO RACK CR-G AS INDICATED. THE DUPLEX FIBRE OPTIC CABLE WILL BE SUPPLIED AND TERMINATED BY OTHERS.			A
ELECTRICAL SERVICES DROPPER		PROVIDE A CUSTOM 316 STAINLESS STEEL ELECTRICAL SERVICES DROPPER FROM THE CEILING TO THE ISLAND BENCH.			A
FIRE INDICATOR PANEL (FIP)		EXISTING BRIGADE MONITORED AS 1670 COMPLAINT FIRE INDICATOR PANEL INCORPORATING THE FDCIE AND EWCIE TO BE RELOCATED AND UPGRADES AS NECESSARY.			A
RECESSED FIRE EVACUATION SPEAKER		RECESSED 5W 8-INCH CONE ALERT AND EVACUATION SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER AND FLUSH GRILLE PAINTED OUT TO MATCH THE CEILING. IN LOCATIONS THE RECESSED SPEAKER IS SHOWN ON AN EXISTING ASBESTOS CEILING IT IS TO BE PROVIDED AS A SURFACE MOUNTED SPEAKER. THE NEW SPEAKERS ARE TO MATCH THE EXISTING.			A
FIRE EVACUATION HORN		SURFACE MOUNTED IP66 ALERT AND EVACUATION HORN SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER. THE NEW HORN SPEAKERS ARE TO MATCH THE EXISTING.			A
SMOKE DETECTOR		SURFACE MOUNTED SMOKE DETECTOR TO AS1670. BK INDICATES THE DETECTOR IS TO BE PROVIDED AS BLACK. THE NEW DETECTORS ARE TO MATCH THE EXISTING.			A
CONCEALED SMOKE DETECTOR		CONCEALED SMOKE DETECTOR TO AS1670 C/W REMOTE INDICATOR AND FAMCO ACCESS BRACKET			A
THERMAL DETECTOR		SURFACE MOUNTED THERMAL DETECTOR TO AS1670. BK INDICATES THE DETECTOR IS TO BE PROVIDED AS BLACK TYPE AS NOTED TYPE AS NOTED THE NEW DETECTORS ARE TO MATCH THE EXISTING.			A
THERMAL DETECTOR IN DUCT		BY GOLD COAST FIRE. DUCT PROBE THERMAL DETECTOR TO AS1670.1 THE NEW DETECTORS ARE TO MATCH THE EXISTING.			A
FIRE ALARM SYSTEM DOOR INTERFACE		FIRE ALARM FAILSAFE INTERFACE TO UNLOCK THE DOOR UPON A FIRE ALARM			A
CONTACTOR C1		AC3 CONTACTOR TO BE LOCATED IN THE COOKING EQUIPMENT ISOLATION ENCLOSURE TO CONTROL THE POWER SUPPLIES TO THE ELECTRIC COOKING EQUIPMENT LOCATED UNDER THE KITCHEN EXHAUST HOOD CANOPY. THE POWER IS TO BE ISOLATED UPON AN ALARM FROM THE FIP OR OPERATION OF THE FIRE SUPPRESSION SYSTEM FSS.			A
FIRE SUPPRESSION SYSTEM (FSS)		FIRE SUPPRESSION SYSTEM BY THE SPECIALIST FIRE SUPPRESSION SYSTEM SPECIALIST. CONNECT THE MECHANICAL CONTACTS IN THE FIRE SUPPRESSION SYSTEM TO THE FIP AND THE CONTROLLER SUCH THAT THE OPERATION OF THE FIRE SUPPRESSION SYSTEM FSS GENERATES AN ALARM IN THE FIP AND ISOLATES THE GAS SUPPLY.			A
OSG 1000V PLUS		EXISTING EXHAUST HOOD CONTROLLER ALL CONTROLS OSG MERLIN 1000V PLUS WALL RECESSED GAS AND ELECTRIC ISOLATION CONTROLLER C/W VENTILATION INTERLOCKING AND GAS PROVING TO BE RELOCATED AND RECOMMISSIONED. PROVIDE THE CONTROLLER WITH A RECESS TRIM KIT.			A
GAS VALVE (GV)		EXISTING GAS VALVE ASSEMBLY ALL CONTROLS OSG GVTJ 500MM GAS VALVE TRANSDUCER JUNCTION BOX TO BE MOUNTED IN LINE WITH THE GAS SUPPLY TO THE ASSOCIATED HOODS COOKING EQUIPMENT TO BE RELOCATED AND RECOMMISSIONED .			A
AIR PRESSURE SWITCH (APS)		EXISTING ALL CONTROLS OSG APS AIR PRESSURE DIFFERENTIAL SWITCH TO BE RELOCATED WITHIN THE NEW KITCHEN EXHAUST HOOD EXHAUST DUCT.			A

ELECTRICAL DESIGN GROUP
ELECTRICAL BUILDING SERVICES CONSULTANTS
P.O. Box 15, SHERWOOD Q. 4075
Phone: 0418 893 338
Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3584a - METROPOLE HOTEL, PROSERPINE **C3584a-0002(A).xls**

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 09 NOVEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
RELAY 1 (R1)		CONTROL RELAY 1 TO BE LOCATED IN THE COOKING EQUIPMENT ISOLATION ENCLOSURE TO INTERFACE THE CONTROLLER TO THE ELECTRIC COOKING EQUIPMENT CONTACTOR C1.			A
RELAY 2 (R2)		CONTROL RELAY 2 TO BE LOCATED IN THE GAS SHUTDOWN IO ENCLOSURE TO INTERFACE THE FIP ALARM OUTPUT TO THE CONTROLLER.			A
RELAY 3 (R3)		CONTROL RELAY 3 TO BE LOCATED IN THE GAS SHUTDOWN IO ENCLOSURE TO INTERFACE THE FIP ALARM INPUT FROM THE FIRE SUPPRESSION SYSTEM FSS.			A

ELECTRICAL DESIGN GROUP BRISBANE PTY LTD ACN 092 710 793
TRADING AS – ELECTRICAL DESIGN GROUP ABN 96 092 710 793