



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3591a - BURLEIGH HEADS HOTEL

C3591a-0008(B).xls

DISTRIBUTION BOARD DB-2

REVISION B - 19 MAY 2026

							REV
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
REMOVE ALL CORCITS MADE REDUNDANT BY THE WORKS. PROVIDE NEW SWITCHGEAR FOR THE FOLLOWING CIRCUITS AND UPDATE THE SCHEDULE AT PRACTICAL COMPLETION							A
P1	1	20	RCBO	2.5	GAMING	CLEANING	A
P2	1	20	RCBO	2.5	GAMING	TV	A
P3							B
P4	1	20	RCBO	2.5	BISTRO	MEET & GREET	A
P5	1	20	RCBO	2.5	EXTERNAL	HEATER	A
P6	1	20	RCBO	2.5	EXTERNAL	HEATER	A
P7	1	20	RCBO	2.5	EXTERNAL	HEATER	A
P8	1	20	RCBO	2.5	EXTERNAL	HEATER	A