

ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3599a - TI-TREE COLLECTIVE

C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1	3000K LED	AMENITY WALL LIGHT ARE PER THE ARCHITECTURAL ELEVATION	AGED BRASS CLEAR SEALING	VOLKER HAUG WALL STITCH	C
L2	2 X 9W 3000K LED	TWO SURFACE MOUNTED CAN LIGHTS WITH A 25MM SEPARATION	WHITE	EQUAL TO RAPID LED COOLY-9 R1165	A
L3	13W 3000K LED	CIRCULATION RECESSED DOWNLIGHT C/W REMOTE TRAILING EDGE DIMMABLE DRIVER	WHITE TRIM	EQUAL TO RAPID LED CAPRI-120 R1352	A
L4	18W 3000K LED	LAUNDRY RECESSED DOWNLIGHT C/W REMOTE TRAILING EDGE DIMMABLE DRIVER	WHITE	EQUAL TO RAPID LED CAPRI-120 R1352	A
L5	18W 3000K LED	AMENITY RECESSED DOWNLIGHT C/W REMOTE TRAILING EDGE DIMMABLE DRIVER	WHITE	EQUAL TO RAPID LED CAPRI-120 R1352	A
L6	25W 3000K LED	BEDROOM RECESSED DOWNLIGHT T C/W REMOTE TRAILING EDGE DIMMABLE DRIVER	WHITE	EQUAL TO RAPID LED CAPRI-140 R1353	C
L7	14.4W/M 3000K LED	LED STRIP WITHIN A ALUMINIUM EXTRUSION C/W OPAL DIFFUSER SCREW FIXED IN PLACE ON TOP OF THE LOWER CEILING TO UPLIGHT THE HIGHER CEILING. ENSURE THERE ARE NO EXPOSED LV CABLES. PROVIDE THE STRIP WITH REMOTE TRAILING EDGE DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED 14.4W/M 3,000K 24VOLT DC IP20 R2334 + R2381 + POWER SUPPLY	C
L8	5W 3000K LED	12V DC GARDEN STAKE LIGHT PROVIDE A REMOTE POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION LOCATED ON THE AS CONSTRUCTED DRAWING. IT IS ACCEPTABLE TO SUPPLY MULTIPLE L8 FITTINGS FROM A COMMON SUITABLY SIZED POWER SUPPLY	BLACK	EQUAL TO RAPID LED SPIKE-5 R6017	A
L9	PROVIDE A CONCEALED POWER SUPPLY CONNECTION TO THE ILLUMINATED SIGN CONFIRM THE CONNECTION LOCATION WITH THE SIGN SUPPLIER.				C
L10	3000K LED	LOBBY WALL LIGHT ARE PER THE ARCHITECTURAL ELEVATION	ANODISED BRONZE / ICE	ARTICOLO STUDIOS EXTERIOR CUBO SINGLE WALL SCONCE	C
L11	3000K LED	WIR WALL LIGHT ARE PER THE ARCHITECTURAL ELEVATION	ANODISED BRONZE / ICE	ARTICOLO STUDIOS EXTERIOR CUBO DOUBLE WALL SCONCE	C



C3599a - TI-TREE COLLECTIVE


C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L12	25W 3000K LED	RECESSED DOWNLIGHT C/W REMOTE TRAILING EDGE DIMMABLE DRIVER	WHITE	EQUAL TO RAPID LED CAPRI-140 R1353	B
L13	10W 3000K LED	EXTERNAL IP65 WALL LIGHT C/W INTEGRAL DRIVER	BLACK	EQUAL TO RAPID LED DAISY-10 R6074	C
L14	20W LED 4000K	600 LONG SURFACE MOUNTED IP65 DIFFUSED BATTEN C/W INTEGRAL ELECTRONIC CONTROL GEAR AND PRESENCE DETECTION SENSOR	GREY	EQUAL TO RAPID LED HAWK-20 R3520-TRI + SENSOR	A
L15	156W RGB LED	UNDERWATER IP68 POOL LIGHT C/W REMOTE POWER SUPPLY AND RGB SELECTOR LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DRAWING.	NA	EQUAL TO RAPID LED R5011-RGB	A
L16	25W 4000K LED	CARPARK LIGHT C/W INTEGRAL DRIVER MOUNTED ON A 3200 HIGH 76 DIA POLE NO TILT	BLACK FITTING BLACK POLE	EQUAL TO RAPID LED R3222-BK-60	A
L17	35W 4000K LED	RECESSED IP65 DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE	EQUAL TO RAPID LED R1098 35W 4000K DALI	C
L18	40W LED 4000K	1200 LONG SURFACE MOUNTED IP65 DIFFUSED BATTEN C/W INTEGRAL ELECTRONIC CONTROL GEAR AND PRESENCE DETECTION SENSOR	GREY	EQUAL TO RAPID LED HAWK-40 R3540-TRI + SENSOR	A
L19	40W LED 4000K	1200 LONG SURFACE MOUNTED IP65 DIFFUSED BATTEN C/W INTEGRAL ELECTRONIC CONTROL GEAR	GREY	EQUAL TO RAPID LED HAWK-40 R3540	A
L20	3W LED 3000K	FLUSH RECESSED WALL LIGHT C/W REMOTE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DRAWINGS. MOUNT THE UNDERSIDE OF THE FITTING AT 300 AFFL. IT IS ACCEPTABLE TO SUPPLY MULTIPLE L20 FITTINGS FROM A COMMON SUITABLY SIZED DRIVER.	WHITE	EQUAL TO RAPID R2161-BK-WW	C
L21	15W 3000K LED	EXTERNAL CAN DOWNLIGHT C/W INTEGRAL DRIVER	WHITE	EQUAL TO RAPID LED COOLY-15 R1166	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3599a - TI-TREE COLLECTIVE

C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L22	3000K LED	PENTHOUSE ARTWORK LIGHT SIGNAGE WALL LIGHT ARE PER THE ARCHITECTURAL ELEVATION ALLOW TO INSTALL	TBA	ALLOW A PC SUM OF \$1000.00 PLUS GST FOR THE SUPPLY OF EACH FITTING	A
L23	3000K LED	PENTHOUSE KITCHEN BENCH PENDANT CONFIRM THE SUSPENSION HEIGHT WITH THE ARCHITECT ALLOW TO INSTALL	TBA	ALLOW A PC SUM OF \$2000.00 PLUS GST FOR THE SUPPLY OF EACH FITTING	A
L24	CEILING ROSE FOR A FUTURE PENDANT LIGHT				B
L25	3000K LED	WALL LIGHT ARE PER THE ARCHITECTURAL ELEVATION	ANODISED BRONZE / ICE	ARTICOLO STUDIOS EXTERIOR CUBO UP DOWN WALL SCONCE	C
L26	3000K LED	WALL LIGHT ARE PER THE ARCHITECTURAL ELEVATION	ANODISED BRONZE / SNOW	ARTICOLO STUDIOS EXTERIOR BALL WALL SCONCE	C
L27	24W 3000K LED	RECESSED ADJUSTABLE DOWNLIGHT C/W REMOTE TRAILING EDGE DIMMABLE DRIVER	WHITE	EQUAL TO RAPID LED BAHAMA R1314 24 W 3000K	C
L28	3000K LED	PENTHOUSE WALL LIGHT ARE PER THE ARCHITECTURAL ELEVATION	AGED BRASS CLEAR SEALING	VOLKER HAUG RUFFLE	C
L29	13W 3000K LED	SHALLOW RECESSED DOWNLIGHT C/W REMOTE DRIVER	WHITE	EQUAL TO RAPID LED MADRID R1051	C
L30	15W 3000K LED	EXTERNAL CAN DOWNLIGHT C/W INTEGRAL DRIVER PROVIDE THE L30 WITH A CUSTOM ANGLED MOUNTING BLOCK SUCH THAT THE FITTING IS VERTICALL. THE MOUNTING BLOCK IS TO BE PAINTED TO MATCH THE CEILING COLOUR AND BE AS SMALL AS PRACTICAL.	WHITE	EQUAL TO RAPID LED COOLY-15 R1166 PLUS CUSTOM MOUNTING BLOCK	C



C3599a - TI-TREE COLLECTIVE


C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S1	14.4W/M 3000K LED	LED STRIP WITHIN A ALUMINIUM EXTRUSION C/W OPAL DIFFUSER SCREW FIXED IN PLACE UNDER THE OVERHEAD CUPBOARDS AS PER THE ARCHITECTURAL DETAILS. ENSURE THERE ARE NO EXPOSED LV CABLES. PROVIDE THE STRIP WITH REMOTE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED 14.4W/M 3,000K 24VOLT DC IP20 R2334 + R2381 + POWER SUPPLY	A
S2	14.4W/M 3000K LED	MULTIPLE RUNS OF HORIZONTAL LED STRIP LIGHT C/W ALUMINIUM EXTRUSION AND OPAL DIFFUSER RECESSED (SCREW FIXED) INTO THE JOINERY AS PER THE ELEVATION AND THE ARCHITECTURAL DETAILS. ENSURE THERE ARE NO EXPOSED LV CABLES. PROVIDE THE STRIP WITH REMOTE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED 14.4W/M 3,000K 24VOLT DC IP20 R2334 + R2382 + POWER SUPPLY	A
S3	14.4W/M 3000K LED	LED STRIP LIGHT C/W ALUMINIUM EXTRUSION AND OPAL DIFFUSER RECESSED (SCREW FIXED) INTO THE JOINERY AS PER THE ELEVATION AND THE ARCHITECTURAL DETAILS. ENSURE THERE ARE NO EXPOSED LV CABLES. PROVIDE THE STRIP WITH REMOTE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED 14.4W/M 3,000K 24VOLT DC IP20 R2334 + R2382 + POWER SUPPLY	A
S4	14.4W/M 3000K LED	1800 LONG LED STRIP WITHIN A ALUMINIUM EXTRUSION C/W OPAL DIFFUSER SCREW FIXED IN PLACE BEHIND THE MIRROR AS PER THE ARCHITECTURAL DETAILS. ENSURE THERE ARE NO EXPOSED LV CABLES. PROVIDE THE STRIP WITH REMOTE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED 14.4W/M 3,000K 24VOLT DC IP20 R2334 + R2381 + POWER SUPPLY	A
S5	14.4W/M 3000K LED	LED STRIP LIGHT C/W ALUMINIUM EXTRUSION AND OPAL DIFFUSER RECESSED (SCREW FIXED) INTO THE CELLAR JOINERY AS PER THE ARCHITECTURAL DETAILS. ENSURE THERE ARE NO EXPOSED LV CABLES. PROVIDE THE STRIP WITH REMOTE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED 14.4W/M 3,000K 24VOLT DC IP20 R2334 + R2382 + POWER SUPPLY	C



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3599a - TI-TREE COLLECTIVE

C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S6	14.4W/M 3000K LED	LED STRIP LIGHT C/W ALUMINIUM EXTRUSION AND OPAL DIFFUSER RECESSED (SCREW FIXED) INTO THE VANITY JOINERY AS PER THE ARCHITECTURAL DETAILS. ENSURE THERE ARE NO EXPOSED LV CABLES. PROVIDE THE STRIP WITH REMOTE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED 14.4W/M 3,000K 24VOLT DC IP20 R2334 + R2382 + POWER SUPPLY	C
S7	14.4W/M 3000K LED	LED STRIP LIGHT C/W ALUMINIUM EXTRUSION AND OPAL DIFFUSER RECESSED (SCREW FIXED) UNDER THE OVERHEAD CUPBOARD AS PER THE ARCHITECTURAL DETAILS. ENSURE THERE ARE NO EXPOSED LV CABLES. PROVIDE THE STRIP WITH REMOTE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED 14.4W/M 3,000K 24VOLT DC IP20 R2334 + R2382 + POWER SUPPLY	C
S8	14.4W/M 3000K LED	LED STRIP LIGHT C/W ALUMINIUM EXTRUSION AND OPAL DIFFUSER RECESSED (SCREW FIXED) INTO THE ENSUITE JOINERY AS PER THE ARCHITECTURAL DETAILS. ENSURE THERE ARE NO EXPOSED LV CABLES. PROVIDE THE STRIP WITH REMOTE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED 14.4W/M 3,000K 24VOLT DC IP20 R2334 + R2382 + POWER SUPPLY	C
S9	NO LONGER REQUIRED				B
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D63 - C90-D63.	WHITE	CLEVERTRONICS LLIFE	A
E2	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D63 - C90-D63.	WHITE	CLEVERTRONICS CLIFE-SM	B
E3	LED	WALL RECESSED EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT CENTERED AT 2400 AFFL. AS2293 CLASSIFICATION C0-D63 - C90-D63.	WHITE	CLEVERTRONICS LLIFE	C
EX BOH	LED	BACK OF HOUSE EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	WHITE	CLEVERTRONICS LCFLED	A



C3599a - TI-TREE COLLECTIVE


C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
EX FOH	LED	FRONT OF HOUSE EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	WHITE	CLEVERTRONICS LUBPRO-SM	A
EX WP	LED	EXIT LIGHT: MAINTAINED WEATHER PROOF 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	WHITE	CLEVERTRONICS LWELED	A
EMERGENCY PACK		LIGHT FITTINGS THAT ARE DESIGNATED AS BEING PROVIDED WITH AN EMERGENCY PACK ARE TO BE PROVIDED WITH AN INTEGRAL AS2293 EMERGENCY PACK. THE FITTINGS ARE TO BE NON MAINTAINED WITH ALL LAMPS SWITCHED AS PER THE LIGHTING CONTROL FOR THAT SPACE UNLESS NOTED OTHERWISE. REFER TO THE SPECIFICATION FOR FURTHER DETAILS OF THE CONFIGURATION AND SWITCHING OF EMERGENCY LIGHTS.			A
CEILING FAN		1320 DIA CEILING FAN	MATT WHITE	HUNTERPACIFIC A3180	C
CEILING FAN CONTROLLER		FAN SPEED CONTROLLER C/W OFF POSITION AND CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. ENSURE THE SPEED CONTROLLER IS COMPATIBLE WITH EH FAN.	WHITE	HAGER FINESSE RANGE	C
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	HAGER FINESSE RANGE	C
ONE-WAY LIGHT SWITCH (DIM)		ONE-WAY LIGHT SWITCH C/W TRAILING EDGE MANUAL POT DIMMER AND CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	HAGER FINESSE RANGE	C
TWO-WAY LIGHT SWITCH		TWO-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1100mm AFFL UNLESS NOTED OTHERWISE.	WHITE	HAGER FINESSE RANGE	C



C3599a - TI-TREE COLLECTIVE


C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
PROXIMITY DETECTOR SWITCH (PD)		ADJUSTABLE FLUSH RECESSED 360 DEGREE PIR PRESENCE DETECTOR TO OPERATE THE ASSOCIATED LIGHTS FOR A PRE-SET AMOUNT OF TIME. ADJUST THE TIME AND SENSITIVITY ON SITE AS DIRECTED BY THE ENGINEER. SUBMIT DETAILS OF THE MOVEMENT DETECTOR SWITCH FOR APPROVAL PRIOR TO ORDERING	WHITE	CLIPSAL	A
CARPARK LIGHTING CONTROL MOVEMENT SENSOR (MS)		CEILING MOUNTED CARPARK LIGHTING CONTROL MOVEMENT SENSORS WIRED IN PARALLEL TO CONTROL THE CARPARK LIGHTING CIRCUITS TO TURN ON FOR FIVE MINUTES WHEN MOVEMENT IS DETECTED. SUBMIT DETAILS OF THE SENSORS AND THE PROPOSED CONFIGURATION FOR APPROVAL.			A
DRIVEWAY ENTRY LIGHTING DAYLIGHT SENSOR (DLS)		DRIVEWAY ENTRY LIGHTING DAYLIGHT SENSOR TO AUTOMATICALLY ADJUST THE L7 FITTING LIGHTING LEVELS TO 800 LUX IN THE DAY TIME AND 160 LUX AT NIGHT.			C
SPECIAL PURPOSE POWER OUTLET		SPECIAL PURPOSE POWER OUTLET. MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O. SIZE AND TYPE AS NOTED	-	CLIPSAL C2000 SERIES	A
BACK OF HOUSE DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300 AFFL U.N.O	WHITE	CLIPSAL C2000 SERIES	A
FRONT OF HOUSE DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300 AFFL U.N.O	WHITE	HAGER FINESSE RANGE	C
DOUBLE POWER OUTLET TYPE Z		DOUBLE POWER OUTLET	MATTE WHITE	ZETR 12-0-W	C
DOUBLE POWER OUTLET (USB)		DOUBLE POWER OUTLET C/W USB A AND USB C CHARGING PORTS AND CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT ABOVE BENCH U.N.O. RATING 10A U.N.O.	WHITE	HAGER FINESSE RANGE	C
MOTORISED BLIND BLANK FACEPLATE (MB)		PROVIDE A BLANK FACEPLATE C/E A 25MM POWER CONDUIT C/W SPARE DRAW WIRE ACK TO THE APARTMENT SWITCHBOARD.	WHITE	HAGER FINESSE RANGE	C
BACK OF HOUSE SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300 AFFL U.N.O.	WHITE	CLIPSAL C2000 SERIES	A
FRONT OF HOUSE SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300 AFFL U.N.O.	WHITE	HAGER FINESSE RANGE	C




C3599a - TI-TREE COLLECTIVE

C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SINGLE POWER OUTLET (FCU)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE MOUNTED IN THE CEILING SPACE FOR THE MECHANICAL FAN COIL UNIT. CONFIRM THE POSITION ON SITE WITH THE MECHANICAL SUB CONTRACTOR. RATING 10A U.N.O.	WHITE	CLIPSAL 2000 SERIES	A
SINGLE POWER OUTLET (WD)		WARMING DRAW SINGLE 10 AMP POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AS PER THE KITCHEN ELEVATION	WHITE	CLIPSAL 2000 SERIES	B
SINGLE POWER OUTLET (EF)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE MOUNTED IN THE CEILING SPACE FOR THE EXHAUST FAN. CONFIRM THE POSITION ON SITE WITH THE MECHANICAL SUB CONTRACTOR. SWITCH THE OUTLET WITH THE ROOM LIGHTS AND PROVIDE IT WITH AN ADJUSTABLE RUN ON TIMER. RATING 10A U.N.O.	WHITE	CLIPSAL 2000 SERIES	A
SINGLE POWER OUTLET (DW)		DISHWASHER SINGLE 10 AMP POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AS PER THE KITCHEN ELEVATION	WHITE	CLIPSAL 2000 SERIES	A
SINGLE POWER OUTLET (MW)		MICROWAVE SINGLE 10 AMP POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AS PER THE KITCHEN ELEVATION	WHITE	CLIPSAL 2000 SERIES	C
SINGLE POWER OUTLET (OV)		OVEN SINGLE 20AMP POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AS PER THE KITCHEN ELEVATION	WHITE	CLIPSAL 2000 SERIES	A
SINGLE POWER OUTLET (RH)		RANGE HOOD SINGLE 10 AMP POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AS PER THE KITCHEN ELEVATION	WHITE	CLIPSAL 2000 SERIES	A
WEATHERPROOF POWER OUTLET (WP)		IP54 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING C/W COVER FLAP OVER SOCKET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 10A U.N.O.	-	CLIPSAL WSCF227F	A
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A



C3599a - TI-TREE COLLECTIVE


C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SINGLE-PHASE ISOLATOR (CT)		COOK TOP POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTAS PER THE KITCHEN ELEVATION PROVIDE A REMOTE ISOLATION SWITCH AS PER AS3000.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT. "RSD" DENOTES ROLLER SHUTTER DOOR SUPPLY - COORDINATE LOCATION ONSITE WITH MOTOR.	-	CLIPSAL WHT35	A
THREE-PHASE ISOLATOR (HWS)		HOT WATER SYSTEM THREE-PHASE WEATHERPROOF ISOLATOR. RATING 32A U.N.O. CONNECT TO THE HWS VIA FLEXIBLE CONDUIT. COORDINATE LOCATION ONSITE WITH THE HYDRAULIC SUB CONTRACTOR.	-	CLIPSAL WHT35	A
FLOOR HEATER (FH)		IPX7 150W / M SQR IN FLOOR HEATER COVERING THE HATCHED AREA INDICATED C/W WALL MOUNTED CONTROL LOCATED ADJACENT THE ROOMS LIGHT SWITCH. THE SYSTEM IS TO CONTAIN AN INTEGRAL THERMOSTAT WITHIN THE FLOOR. ENSURE THE IN FLOOR HEATER IS COMPATIBLE WITH THE FLOOR FINISH. SUBMIT DETAILS OF THE HEATER AND CONTROL FOR APPROVAL.	WHITE	CLIPSAL ICONIC ESSENCE FACEPLATE	A
SMOKE ALARM TEST FACILITY (TF)		SURFACE MOUNTED SMOKE ALARM TEST / RESET FACILITY TO TEST / RESET THE ASSOCIATED APARTMENTS SMOKE ALARMS.			A
SINGLE POWER OUTLET (HT)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE MOUNTED IN THE CEILING SPACE FOR THE HEATED TOWEL RAIL SWITCHED WITH THE LIGHTING CIRCUIT. RATING 10A U.N.O.	WHITE	CLIPSAL 2000 SERIES	B
SMOKE ALARM (S)		SURFACE MOUNTED OPTICAL PHOTOELECTRIC SMOKE ALARM TO AS3786 C/W HARDWIRED MAINS POWER SUPPLY AND A TAMPER PROOF 10 YEAR LITHIUM BATTERY WITH ALL SMOKE ALARMS WITHIN AN APARTMENT INTERCONNECTED SUCH THAT ALL ALARMS WITHIN THAT APARTMENT SOUND SIMULTANEOUSLY.			A
EV CHARGER (EVC)		PROVIDE A 25MM POWER CONDUIT AND A 25MM COMMUNICATIONS CONDUIT C/W DRAW WIRES FROM A FLUSH JUNCTION BOX AT THE FUTURE EVC LOCATION TO THE BASEMENT WLECTRICAL ROOM.			B
NBN PREMISE CONNECTION DEVICE (PCD)		NBN COMPLIANT PREMISES CONNECTION DEVICE. CONNECT THE PCD TO THE TELSTRA PIT VIA AN NBN COMPLIANT LEAD-IN CONDUIT.			A
NBN SPLITTER DISTRIBUTION TERMINAL (SDT8)		NBN COMPLIANT TYPE 8 OPTICAL SPLITTER.			A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3599a - TI-TREE COLLECTIVE

C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
NBN NETWORK TERMINATION UNIT (NTD)		NBN COMPLIANT NETWORK TERMINATION UNIT TO BE PROVIDED IN ACCORDANCE WITH THE NBN REQUIREMENTS.			A
CAT 6 COMMUNICATIONS OUTLET		CAT 6 COMMUNICATIONS OUTLET C/W ENGRAVED PORT IDENTIFICATION ON THE FACEPLATE. CABLE EACH APARTMENT OUTLET TO THE ASSOCIATED APARTMENTS COMMUNICATION HUB AND THE COMMUNAL OUTLETS TO THE COMMUNAL HUB VIA CAT 6 UTP CABLE. MOUNT AT 300 AFFL U.N.O.	WHITE	HAGER FINESSE RANGE	A
COMMUNICATIONS HUB		MULTI GANG FACE PLATES C/W ONE CAT 6 PORT PER COMMUNICATIONS OUTLET. ENGRAVE EACH PORT WITH THE ASSOCIATED OUTLET NUMBER.	WHITE	CLIPSAL 2000 SERIES	A
COMMUNICATIONS RACK (CR-A)		PROVIDE CR-A AS A 12 RU WALL MOUNTED RACK TO HOUSE THE			A
MSB		MAIN SWITCHBOARD IN ACCORDANCE WITH THE QECM V4 REQUIREMENTS. REFER TO THE NOTES AND POWER SCHEMATIC.			A
DB-P		COMMUNITY POWER DISTRIBUTION BOARD REFER TO THE NOTES AND DB SCHEDULE.			A
DB-L		COMMUNITY LIGHTING DISTRIBUTION BOARD REFER TO THE NOTES AND DB SCHEDULE.			A
DB-E		COMMUNITY EV CHARGING DISTRIBUTION BOARD REFER TO THE NOTES AND DB SCHEDULE.			A
DB-1		APARTMENT 1 DISTRIBUTION BOARD REFER TO THE NOTES AND DB SCHEDULE.			A
DB-2		APARTMENT 2 DISTRIBUTION BOARD REFER TO THE NOTES AND DB SCHEDULE.			A
DB-3		APARTMENT 3 DISTRIBUTION BOARD REFER TO THE NOTES AND DB SCHEDULE.			A
DB-4		APARTMENT 4 DISTRIBUTION BOARD REFER TO THE NOTES AND DB SCHEDULE.			A
DB-5		APARTMENT 5 DISTRIBUTION BOARD REFER TO THE NOTES AND DB SCHEDULE.			A
MSSB		MECHANICAL SERVICES SWITCHBOARD SUPPLIED AS PART OF THE MECHANICAL SUB CONTRACT			B
POOL BOARD		POOL DISTRIBUTION BOARD SUPPLIED AS PART OF THE POOL SUB CONTRACT			A
EXIT LOOP		ACCESS CONTROL INSITU ROLLER SHUTTER DOOR EXIT LOOP			A




C3599a - TI-TREE COLLECTIVE

C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
FIRE INDICATOR PANEL (FIP)		BRIGADE MONITORED FIRE INDICATOR PANEL			A
ASPERATING SMOKE DETECTOR		LIFT SHAFT ASPERATING ADDRESSABLE SMOKE DETECTOR WITH THE UNIT LOCATED IN A CONCEALLED ACCESSIBLE POSITION IN THE CEILING SPACE. PROVIDE THE DETECTOR WITH A WHITE REMOTE INDICATOR AND ACCESS BRACKET AS REQUIRED.			B
FIRE EVACUATION HORN		SURFACE MOUNTED TWO-TONE 30W ALERT AND EVACUATION HORN SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER. MOUNT AT HIGH LEVEL.			B
FIRE EVACUATION RECESSED SPEAKER		RECESSED 5W TWO-TONE 8-INCH CONE ALERT AND EVACUATION SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER AND FLUSH GRILLE PAINTED OUT TO MATCH THE CEILING.			B
FIRE EVACUATION SURFACE MOUNTED SPEAKER		SURFACE MOUNTED 5W TWO-TONE 8-INCH CONE ALERT AND EVACUATION SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER AND FLUSH GRILLE PAINTED OUT TO MATCH THE CEILING.			C
FIRE ALARM STROBE		WALL MOUNTED FIRE ALARM STROBE LIGHT AS PER AS1670.1			B
QECM V4 WHOLE CURRENT THREE PHASE METER (M)		QECM V4 WHOLE CURRENT THREE PHASE METER			A
LOAD MANAGEMENT MONITOR (LM)		EV CHARGING LOAD MANAGEMENT MONITORING POINT			A
NCC PART J9 D3 ENERGY METER (EM)		ENERGY MONITORING SYSTEM METER AS PER J9D3 OF THE NCC BCA 2022			A
GENERATION SIGNALLING DEVICE (GSD)		NO LONGER REQUIRED			B
DEMAND RESPONSE SITE CONTROLLER (DRSC)		NO LONGER REQUIRED			B
ELECTRIC VEHICLE CHARGING ISOLATION SWITCH (CIS)		ELECTRIC VEHICLE CHARGING ISOLATION SWITCH PUSH BUTTON WIRED TO THE EV CHARGER SUPPLY CIRCUIT BREAKER SHUNT TRIP TO ISOLATE THE POWER TO THE ELECTRIC VEHICLE CHARGERS. MOUNTED AT 1800mm AFFL UNLESS NOTED OTHERWISE. PROVIDE COLOURED ENGRAVED TEXT AS PER THE CIS ELEVATION.	WHITE	CLIPSAL C2000 SERIES 30USM	A
VIDEO INTERCOM CALL STATION (ICS1)		FLUSH WALL MOUNTED IP VANDAL RESISTANT MASTER 2MP VIDEO INTERCOM CALL STATION TO ALLOW SPECIFIC APARTMENTS TO BE CONTACTED VIA THE APARTMENTS VIDEO INTERCOM HANDSET. THE CALL STATION IS TO CONTAIN BACK LITE CALL BUTTONS. PROVIDE DETAILS OF THE VIDEO INTERCOM SYSTEM FOR APPROVAL.			B



C3599a - TI-TREE COLLECTIVE

C3599a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 28 APRIL 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
VIDEO INTERCOM CALL STATION (ICS2)		BOLLARD MOUNTED IP VANDAL RESISTANT MASTER 2MP VIDEO INTERCOM CALL STATION TO ALLOW SPECIFIC APARTMENTS TO BE CONTACTED VIA THE APARTMENTS VIDEO INTERCOM HANDSET. THE CALL STATION IS TO CONTAIN BACK LITE CALL BUTTONS. PROVIDE THE BOLLARD AS A CUSTOM POWDERCOATED BLACK BOLLARD. PROVIDE DETAILS OF THE VIDEO INTERCOM SYSTEM AND THE BOLLARD FOR APPROVAL.			B
VIDEO INTERCOM CALL STATION (ICS3)		BOLLARD MOUNTED IP VANDAL RESISTANT MASTER 2MP VIDEO INTERCOM CALL STATION TO ALLOW SPECIFIC APARTMENTS TO BE CONTACTED VIA THE APARTMENTS VIDEO INTERCOM HANDSET. THE CALL STATION IS TO CONTAIN BACK LITE CALL BUTTONS. PROVIDE THE BOLLARD AS A CUSTOM POWDERCOATED BLACK BOLLARD. PROVIDE DETAILS OF THE VIDEO INTERCOM SYSTEM AND THE BOLLARD FOR APPROVAL.			B
VIDEO INTERCOM HANDSET		FLUSH WALL MOUNTED IP VIDEO INTERCOM SLAVE HAND FREE HAND SET / 7 INCH SCREEN TO ALLOW COMMUNICATION WITH THE ASSOCIATED CALL STATION. INTERFACE THE VIDEO INTERCOM SYSTEM TO THE ACCESS CONTROL SYSTEM SUCH THAT ACCESS CAN BE GRANTED TO THE APARTMENT VIA THE ACCESS ROUTE FROM THE ASSOCIATED CALL STATION. PROVIDE A FUNCTIONAL DESCRIPTION OF THE OPERATION OF THE VIDEO INTERCOM SYSTEM AND THE ACCESS CONTROL SYSTEM FOR APPROVAL.			B
CAMERA (C)		NO LONGER REQUIRED			B
ELECTRIC STRIKE (ES)		PROVIDE A CONCEALED ELECTRIC STRIKE COMPATIBLE WITH THE DOOR TO ALLOW THE ACCESS CONTROL SYSTEM TO CONTROL THE DOOR.			A
LIFT INTERFACE MODULE (LIM)		PROVIDE AN INTERFACE TO THE LIFT TO ALLOW A CAMERA TO BE INSTALLED IN THE LIFT AND THE LIFT TO BE CONTROLLED BY THE ACCESS CONTROL SYSTEM.			A
GATE MOTOR INTERFACE (GM)		PROVIDE AN INTERFACE TO THE GATE MOTOR CONTROLLER TO ALLOW IT TO BE CONTROLLED BY THE ACCESS CONTROL SYSTEM.			B
ROLLER SHUTTER DOOR INTERFACE (RSD)		PROVIDE AN INTERFACE TO THE ROLLER SHUTTER DOOR CONTROLLER TO ALLOW IT TO BE CONTROLLED BY THE ACCESS CONTROL SYSTEM. THE RSD IS TO BE OPENED VIA FOBS OR THE OPERATION OF THE INSITU INDUCTION LOOP.			A
CARD READER (CR)		WALL MOUNTED VANDAL RESISTANT ACCESS CONTROL CARD READER.			A
PV INVERTER (INV)		NO LONGER REQUIRED			B
MATV HEAD END		PROVIDE A MATV HEADEND WITH ALL NECESSARY POWER SUPPLIES TO DISTRIBUTE THE FREE TO AIR AND FOXTEL TELEVISION SERVICES TO ALL MATV OUTLETS VIA A 5 WIRE SYSTEM IN ACCORDANCE WITH THE FOXTEL REQUIREMENTS. PROVIDE A SHOP DRAWING OF THE MATV SYSTEM INCLUDING THE MATV HEADEND FOR APPROVAL.			A
TELEVISION MATV OUTLET		MATV OUTLET CONNECTED TO THE ANTENNA IN STAR CONFIGURATION VIA RG6 CABLE TO FACILITATE THE DISTRIBUTION OF FOXTEL AND FREE TO AIR SERVICES. MOUNT AT 300mm AFFL U.N.O.	WHITE	HAGER FINESSE RANGE	C