



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3646a - CLUB TAVERN CABOOLTURE

C3646a-0005(C).xls

DISTRIBUTION BOARD DB-1

REVISION C - 29 MAY 2026

							REV
REFER TO THE NOTES FOR ADDITIONAL REQUIREMENTS. MODIFY THE EXISTING DB-1 INTEGRAL TO THE MSB TO ACCOMMODATE THE FOLLOWING CIRCUITS. REMOVE ALL SWITCHGEAR MADE REDUNDANT BY THE WORKS. ENSURE THE SCHEDULE INCLUDES THE CIRCUIT USE AND LOCATION.							B
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5	BISTRO	REF	A
P2	1	25	RCBO	6.0	BISTRO	COFFEE	A
P3	1	20	RCBO	2.5	BISTRO	TV	A
P4	1	20	RCBO	2.5	BISTRO	CLEANING	A
P5	1	20	RCBO	2.5	BISTRO	AUTO DOOR	A
P6	1	20	RCBO	2.5	BISTRO	15A OUTLET	C
P7	1	20	RCBO	2.5	BISTRO	15A OUTLET	C
P8	1	20	RCBO	2.5	BISTRO	SOFT SERVE	C
L1	1	20	RCBO	2.5		SIGN	A
L2	1	20	RCBO	2.5		SIGN	A
L3	1	20	RCBO	2.5		LIGHTING	A
L4	1	20	RCBO	2.5		LIGHTING	A
L5	1	20	RCBO	2.5		LIGHTING	A
L6	1	20	RCBO	2.5		LIGHTING	A
L7	1	20	RCBO	2.5		LIGHTING	A
L8	1	20	RCBO	2.5		LIGHTING	A
L9	1	20	RCBO	2.5		LIGHTING	A
L10	1	20	RCBO	2.5		LIGHTING	A